

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County PRATT	Fraction SE 1/4 NW 1/4 NE 1/4	Section number 20	Township number T 29	Range number S 11 W E/W																																																			
2. Distance and direction from nearest town or city: 8 E & 3/4 N of Sawyer			3. Owner of well: Dale Tucker R.R. or street: City, state, zip code: Lawrence, KS																																																						
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="text-align: center;"> </div> <div style="margin-left: 20px;"> <p>Sketch map:</p> </div> </div>			6. Bore hole dia. 30 in. Completion date: 18 July 77 Well depth 170 ft.																																																						
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary																																																						
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr><td>Soil</td><td>0</td><td>2</td></tr> <tr><td>Clay, white & gyp & sand</td><td>2</td><td>55</td></tr> <tr><td>Sand, Fine to coarse & med gravel w/ clay streaks</td><td>55</td><td>95</td></tr> <tr><td>Clay, Tan & gray</td><td>95</td><td>100</td></tr> <tr><td>Sand, Fine to coarse</td><td>100</td><td>103</td></tr> <tr><td>Sand, Fine to coarse & med gravel - med loose</td><td>103</td><td>107</td></tr> <tr><td>Clay, Green</td><td>107</td><td>109</td></tr> <tr><td>Sand, Fine to coarse & med gravel - med hard</td><td>109</td><td>121</td></tr> <tr><td>Clay, Tan & white - hard</td><td>121</td><td>155</td></tr> <tr><td>Sand, Fine to coarse w/ hard clay streaks</td><td>155</td><td>165</td></tr> <tr><td>Sand, Fine to coarse & med gravel - loose</td><td>165</td><td>170</td></tr> <tr><td>Shale, Red</td><td>170</td><td>180</td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </tbody> </table>				From	To	Soil	0	2	Clay, white & gyp & sand	2	55	Sand, Fine to coarse & med gravel w/ clay streaks	55	95	Clay, Tan & gray	95	100	Sand, Fine to coarse	100	103	Sand, Fine to coarse & med gravel - med loose	103	107	Clay, Green	107	109	Sand, Fine to coarse & med gravel - med hard	109	121	Clay, Tan & white - hard	121	155	Sand, Fine to coarse w/ hard clay streaks	155	165	Sand, Fine to coarse & med gravel - loose	165	170	Shale, Red	170	180													9. Casing: Material SLC Height: 12 in. above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 1 1/2 in. to 1 7/8 in. depth 170 ft. Wall Thickness: 1/8 in. or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> in. depth <input type="checkbox"/> ft. gage No. 188			
				From	To																																																				
Soil	0	2																																																							
Clay, white & gyp & sand	2	55																																																							
Sand, Fine to coarse & med gravel w/ clay streaks	55	95																																																							
Clay, Tan & gray	95	100																																																							
Sand, Fine to coarse	100	103																																																							
Sand, Fine to coarse & med gravel - med loose	103	107																																																							
Clay, Green	107	109																																																							
Sand, Fine to coarse & med gravel - med hard	109	121																																																							
Clay, Tan & white - hard	121	155																																																							
Sand, Fine to coarse w/ hard clay streaks	155	165																																																							
Sand, Fine to coarse & med gravel - loose	165	170																																																							
Shale, Red	170	180																																																							
<div style="display: flex; align-items: center;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">1 Mile</div> <div style="margin-left: 10px;"> <p>1 Mile</p> </div> </div>			10. Screen: Manufacturer's name Blount & Cook Type perforated Dia. 16" Slot/gauze 1/25 & 1/100 Length 40' Set between 85-95 ft. and 101-121 ft. 160-170 ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 1/2																																																						
			11. Static water level: 50 ft. below land surface Date 18 July 77																																																						
<div style="display: flex; align-items: center;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">1 Mile</div> <div style="margin-left: 10px;"> <p>1 Mile</p> </div> </div>			12. Pumping level below land surfaces: 80 ft. after 1 hrs. pumping 800 g.p.m. 88 ft. after 1 hrs. pumping 900 g.p.m. Estimated maximum yield 1000 g.p.m.																																																						
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>																																																						
<div style="display: flex; align-items: center;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">1 Mile</div> <div style="margin-left: 10px;"> <p>1 Mile</p> </div> </div>			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade																																																						
			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.																																																						
<div style="display: flex; align-items: center;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">1 Mile</div> <div style="margin-left: 10px;"> <p>1 Mile</p> </div> </div>			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type AKA Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																																																						
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Simmons Model number <input type="checkbox"/> HP 80 Volts <input type="checkbox"/> Length of drop pipe 100 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																																						
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CENTRAL Well & Pump 325 Business name 121 S. Taylor Pratt License No. 18 July 77 Address Shannonville Signed Shannonville Date 18 July 77 Authorized representative																																																						
19. Remarks: 8' X 12' X 8" slab poured at surface																																																									

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5