


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County PRATT	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 24	Township number T 29	Range number S R 11 W E/M
2. Distance and direction from nearest town or city: 2W 5 3/4 N Street address of well location if in city: 606 NASHVILLE, KS			3. Owner of well: ALLEN SCHNITTKER R.R. or street: City, state, zip code: ST. LEO, KS.		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 			6. Bore hole dia. 30 in. Completion date 12/24/77 Well depth 64 ft.		
			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material STL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 44 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1188		
5. Type and color of material			From	To	
SOIL, SANDY			0	2	10. Screen: Manufacturer's name WA BROWN & COOK
SAND, FINE			2	6	Type PROFLO Dia. 16"
CLAY, TAN W/ SAND			6	11	Slot/gauze 1/8 Length 20'
SAND, FINE TO COARSE			11	31	Set between 44 ft. and 54 ft. and 54 ft. and 64 ft. PROFLO slot
SAND, COARSE & MED TO COARSE GRAVEL			31	64	Gravel pack? Yes Size range of material 1/4 - 1/2
W/SOME BOULDERS (LOOSE)					11. Static water level: 15 ft. below land surface Date 12/24/77
CLAY, TAN			64	80	12. Pumping level below land surfaces: 38 ft. after 2 hrs. pumping 831 g.p.m. 42 ft. after 1/2 hrs. pumping 1000 g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.
SHALE, RED			80	90	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
					15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: AWB ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name FLOWAY Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 50 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: 1765 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 32, 686, 5 X 10' CONCRETE SLAB AT SURFACE 29 11 24 NAX		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 325 Business name License No. Address 1215 TAYLOR PRATT Signed Pat Monnich Date 12/24/77 Authorized representative		

29 11 24 NAX
Sec 24 NE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5