


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pratt	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 30	Township number T 29 S R 11 E	Range number 11
2. Distance and direction from nearest town or city: 3 miles Northwest of Isabelle, KS Street address of well location if in city:				3. Owner of well: John Collett R.R. or street: 4800 Main Street City, state, zip code: Kansas City, MO 64112		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:				6. Bore hole dia. 24 in. Completion date 9-14-76 Well depth 186 ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				From	To	9. Casing: Material steel Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP see 2 page PVC Weight 30.3 lbs./ft. Dia. 16 in. to 2 ft. depth Wall Thickness: inches or Dia. 16 in. to 2 ft. depth gage No. 7 ga.
sandy top soil				0	3	10. Screen: Manufacturer's name Doerr & Cook Type double-slot Dia. 16" Slot/gauze 1/8" Length SEE PG. 2 Set between see p. 2 ft. and ----- ft. ----- ft. and ----- ft. Gravel pack? yes Size range of material 3/8-20
sandy clay streak & white clay				3	35	11. Static water level: 67 ft. below land surface Date 9-13-76
hard hard white clay				35	58	12. Pumping level below land surfaces: N/C ----- ft. after ----- hrs. pumping ----- g.p.m. ----- ft. after ----- hrs. pumping ----- g.p.m. Estimated maximum yield ----- g.p.m.
sand & gravel				58	62	13. Water sample submitted: ----- mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date -----
soft sandy clay				62	72	14. Well head completion: 12 inches above grade <input type="checkbox"/> Pitless adapter
sand & gravel & clay streaks				72	87	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
soft sandy clay, hard streaks at 98'				87	99	16. Nearest NONE KNOWN source of possible contamination: ft. ----- Direction ----- Type ----- Well disinfected upon completion? ----- Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
fine sand & soft sandy clay				99	103	17. Pump: Not installed Manufacturer's name FMC Corp/Peerless Model number 12LB-5 HP 80 Volts --- Length of drop pipe 150 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
sand & gravel				103	116	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Equip. Inc. 185 Business name Great Bend, KS 67530 License No. ----- Address ----- Signed D.W. Clarke Date 9-17-76 Authorized representative
soft brown sandy clay				116	121	
sand & gravel & cemented streaks				121	122	
soft sandy clay				122	130	
sand & gravel & clay streaks				130	141	
hard red sandy clay				141	157	
sand -- embedded sand & gravel				157	164	
(cont. p. 2) (Use a second sheet if needed)						
18. Elevation:		19. Remarks: Formation Log & Casing & Screen record are on page -2-				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

-- Page 2

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County

Pratt

Fraction

1/4 SW 1/4 NW 1/4

Section number

30

Township number

T 29 S

Range number

R 11 E

1. Location of well:

2. Distance and direction from nearest town or city:

3. Owner of well: John Collett (Continued from page 1)

Street address of well location if in city:

R.R. or street:

City, state, zip code:

4. Locate with "X" in section below:

Sketch map:

5. Type and color of material

From

To

hard clay

164

167

sandy clay & thin gravel streaks

167

175

sand & gravel & clay streaks

175

185

brown clay & red bed

185

186

CASING & SCREEN:

Casing

0

104

Doerr Screen Double-slot

104

108

Cook Screen

108

118

Doerr Screen Double-slot

118

122

Cook Screen

122

142

Casing

142

168

Doerr Screen Double-slot

168

176

Cook Screen

176

186

(Use a second sheet if needed)

6. Bore hole dia. _____ in. Completion date _____

Well depth _____ ft.

7. Cable tool _____ Rotary _____ Driven _____ Dug _____

Hollow rod _____ Jetted _____ Bored _____ Reverse rotary _____

8. Use: _____ Domestic _____ Public supply _____ Industry _____

_____ Irrigation _____ Air conditioning _____ Stock _____

_____ Lawn _____ Oil field water _____ Other _____

9. Casing: Material _____ Height: Above or below _____

Threaded _____ Welded _____ Surface _____ in.

RMP _____ PVC _____ Weight _____ lbs./ft.

Dia. _____ in. to _____ ft. depth Wall Thickness _____ inches or

Dia. _____ in. to _____ ft. depth gage No. _____

10. Screen: Manufacturer's name _____

Type _____ Dia. _____

Slot/gauze _____ Length _____

Set between _____ ft. and _____ ft.

_____ ft. and _____ ft.

Gravel pack? _____ Size range of material _____

11. Static water level: _____ mo./day/yr.

_____ ft. below land surface Date _____

12. Pumping level below land surfaces:

_____ ft. after _____ hrs. pumping _____ g.p.m.

_____ ft. after _____ hrs. pumping _____ g.p.m.

Estimated maximum yield _____ g.p.m.

13. Water sample submitted: _____ mo./day/yr.

Yes _____ No _____ Date _____

14. Well head completion: _____

Pitless adapter _____ Inches above grade _____

15. Well grouted? _____

With: _____ Neat cement _____ Benonite _____ Concrete _____

Depth: From _____ ft. to _____ ft.

16. Nearest source of possible contamination:

ft. _____ Direction _____ Type _____

Well disinfected upon completion? _____ Yes _____ No _____

17. Pump: _____ Not installed _____

Manufacturer's name _____

Model number _____ HP _____ Volts _____

Length of drop pipe _____ ft. capacity _____ g.p.m.

Type: _____

_____ Submersible _____ Turbine _____

_____ Jet _____ Reciprocating _____

_____ Centrifugal _____ Other _____

18. Elevation:

19. Remarks:

20. Water well contractor's certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Business name _____ License No. _____

Address _____

Signed _____ Date _____

Authorized representative _____

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023