


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>PRATT</u>	Fraction <u>Center NE 1/4</u>	Section number <u>35</u>	Township number <u>29</u>	Range number <u>16</u>	E/W
2. Distance and direction from nearest town or city: <u>2 North Isabel Kans.</u>		3. Owner of well: <u>Search Mining Co.</u>		R.R. or street: City, state, zip code: <u>Wichita Kans.</u>			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile		Sketch map: 		6. Bore hole dia. <u>8</u> in. Completion date <u>6-7-76</u> Well depth <u>100</u> ft.			
5. Type and color of material		From		To		7. <u>Cable tool</u> <u>Rotary</u> <u>Driven</u> <u>Dug</u> <u>Hollow rod</u> <u>Jetted</u> <u>Bored</u> <u>Reverse rotary</u>	
						8. Use: <u>Domestic</u> <u>Public supply</u> <u>Industry</u> <u>Irrigation</u> <u>Air conditioning</u> <u>Stock</u> <u>Lawn</u> <u>Oil field water</u> <u>Other</u>	
						9. Casing: Material <u>Plastic</u> Height: Above or below Threaded <u>Welded</u> <u>Surface</u> <u>12</u> in. RMP <u>PVC</u> <u>X</u> Weight <u>2873</u> lbs./ft. Dia <u>5</u> in. to <u>100</u> ft. depth Wall Thickness: inches or Dia. <u>in.</u> to <u>ft.</u> depth gage No. <u>2265</u>	
						10. Screen: Manufacturer's name <u>Meyer (Water Well)</u> Type <u>Slotted</u> Dia. <u>5</u> in. Slot/gauze <u>1/8</u> in. Length <u>20</u> ft. Set between <u>8</u> ft. and <u>100</u> ft. ft. and <u>ft.</u> Gravel pack? <u>X</u> Size range of material <u>8-14</u>	
						11. Static water level: <u>40</u> ft. below land surface Date <u>6-10-76</u> mo./day/yr.	
				12. Pumping level below land surfaces: <u>60</u> ft. after <u>1</u> hrs. pumping <u>40</u> g.p.m. <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> Estimated maximum yield <u>100</u> g.p.m.			
				13. Water sample submitted: <u>Yes</u> <u>X</u> No Date <u>6-10-76</u> mo./day/yr.			
				14. Well head completion: <u>Pitless adapter</u> <u>12</u> inches above grade			
				15. Well grouted? <u>A</u> With: <u>Neat cement</u> <u>X</u> Bentonite <u>Concrete</u> Depth: From <u>0</u> ft. to <u>10</u> ft.			
				16. Nearest source of possible contamination: ft. <u>Direction</u> <u>Type</u> Well disinfected upon completion? <u>Yes</u> <u>No</u>			
				17. Pump: <u>X</u> Not installed Manufacturer's name <u>HP</u> <u>Volts</u> Model number <u>HP</u> <u>Volts</u> Length of drop pipe <u>ft.</u> capacity <u>g.p.m.</u> Type: <u>Submersible</u> <u>Turbine</u> <u>Jet</u> <u>Reciprocating</u> <u>Centrifugal</u> <u>Other</u>			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Meyer Water Well, Inc.</u> Business name <u>143</u> License No. Address <u>143</u> Signed <u>Jeffrey</u> Date <u>6-10-76</u> Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5