

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County PRATT	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 2	Township number T 29 S R 12 W E/W	Range number
2. Distance and direction from nearest town or city: 5 E & 4 N OF SAWYER, KS			3. Owner of well: NEWMAN WHEATLY FARMS		
Street address of well location if in city:			R.R. or street: ISABEL, KS		
4. Locate with "X" in section below:			Sketch map:		
			6. Bore hole dia. 30 in. Completion date 6 JULY 79 Well depth 187 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material STL Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 32.7 lbs./ft. Dia. 16 in. to 107 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
5. Type and color of material			From	To	10. Screen: Manufacturer's name WA BROWN
SOIL			0	2	Type FLUO Dia. 16
CLAY, W/WHITE & TAN			2	35	Slot/gauze 1/8 Length 80'
SAND, FINE TO COARSE & MED GRAVEL			35	56	Set between 107 ft. and 187 ft.
CLAY, TAN & WHITE			56	72	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 3/8
SAND, FINE TO COARSE & MED GRAVEL			72	120	11. Static water level: 66' ft. below land surface Date 6 JULY 79
CLAY, WHITE			120	128	12. Pumping level below land surfaces: 75 ft. after 1 hrs. pumping 800 g.p.m. 78 ft. after 1 hrs. pumping 1000 g.p.m. Estimated maximum yield 1500 g.p.m.
SAND, FINE TO COARSE & MED GRAVEL			128	187	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
SAND, VERY FINE WITH CLAY STREAKS			187	204	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type NONE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name SIMMONS Model number SP12 HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 120 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:			19. Remarks: 5'X12'X8" Slab Poured at Surface		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CENTRAL WELL & PUMP 325 Business name License No. Address 1221 N. MAIN PRATT Signed J. H. Honomichl Date AUG 79 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5