

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County: <u>PRATT</u>	Fraction: <u>NW 1/4 SW 1/4 SE 1/4</u>	Section number: <u>23</u>	Township number: <u>T 29 S</u>	Range number: <u>R 12 W E/W</u>
2. Distance and direction from nearest town or city: <u>4 E of Sawyer, Kas</u>			3. Owner of well: <u>DOYLE BOYD</u>		
Street address of well location if in city:			City, state, zip code: <u>Sawyer, Kas</u>		
4. Locate with "X" in section below:			Sketch map:		
5. Type and color of material			From	To	
<u>Soil</u>			<u>0</u>	<u>2</u>	
<u>Silt, Sandy</u>			<u>2</u>	<u>12</u>	
<u>Sand, Coarse &amp; Coarse gravel</u>			<u>12</u>	<u>18</u>	
<u>Clay, Tan</u>			<u>18</u>	<u>37</u>	
<u>Sand, fine to Coarse &amp; fine gravel</u>			<u>37</u>	<u>51</u>	
<u>Clay, Sandy tan</u>			<u>51</u>	<u>63</u>	
<u>Sand, Very fine to Coarse</u>			<u>63</u>	<u>79</u>	
<u>Sand, fine to Coarse &amp; med gravel</u>			<u>79</u>	<u>110</u>	
6. Bore hole dia. <u>10</u> in. Completion date <u>13 July 78</u>					
Well depth <u>110</u> ft.					
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug					
<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry					
<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock					
<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
9. Casing: Material <input type="checkbox"/> Height: <u>Above</u> or below					
Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in.					
RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>12</u> lbs./ft.					
Dia <u>5</u> in. to <u>90</u> ft. depth Wall Thickness: inches or					
Dia. <u>5</u> in. to <u>90</u> ft. depth gage No. <u>258</u>					
10. Screen: Manufacturer's name <u>Peelers</u>					
Type <u>Sawtooth</u> Dia. <u>50"</u>					
Slot/gauze <u>48</u> Length <u>30'</u>					
Set between <u>90</u> ft. and <u>110</u> ft.					
Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/8 X 1/4</u>					
11. Static water level: <u>60</u> ft. below land surface Date <u>13 July 78</u>					
12. Pumping level below land surfaces:					
<u>        </u> ft. after <u>        </u> hrs. pumping <u>        </u> g.p.m.					
<u>        </u> ft. after <u>        </u> hrs. pumping <u>        </u> g.p.m.					
Estimated maximum yield <u>30</u> g.p.m.					
13. Water sample submitted: <u>        </u> mo./day/yr.					
Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>        </u>					
14. Well head completion:					
<input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade					
15. Well grouted? <input checked="" type="checkbox"/>					
With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete					
Depth: From <u>4</u> ft. to <u>14</u> ft.					
16. Nearest source of possible contamination:					
ft. <u>110</u> Direction <u>NE</u> Type <u>Septic</u>					
Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
17. Pump: <input type="checkbox"/> Not installed					
Manufacturer's name <u>Star Rite</u>					
Model number <u>20</u> HP <u>1</u> Volts <u>        </u>					
Length of drop pipe <u>90</u> ft. capacity <u>25</u> g.p.m.					
Type:					
<input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine					
<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating					
<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:		20. Water well contractor's certification:	
Topography:		<u>4' X 4' X 4" slab poured below pitless adapter</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
<input type="checkbox"/> Hill				<u>Central Well &amp; Pump 325</u>	
<input type="checkbox"/> Slope				Business name <u>21 S. Taylor Pratt Kas</u>	
<input checked="" type="checkbox"/> Upland				Address <u>        </u>	
<input type="checkbox"/> Valley				Signed <u>Robertonmichl</u> Date <u>20 July 78</u>	
				Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5