

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>PRATT</b>	Fraction <b>NW 1/4 NW 1/4 NW 1/4</b>	Section number <b>29</b>	Township number <b>T 29</b>	Range number <b>S R 12W E/W</b>
2. Distance and direction from nearest town or city: <b>1 E of Sawyer Ks</b>			3. Owner of well: <b>VERNON HIRT</b>			
Street address of well location if in city:			R.R. or street: City, state, zip code: <b>Sawyer, Ks</b>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>10</b> in. Completion date <b>12 Sept 78</b> Well depth <b>175</b> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Soil		0	2	9. Casing: Material <input type="checkbox"/> Threated <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <b>5</b> in. to <b>110</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>258</b>		
clay, Brown		2	30	10. Screen: Manufacturer's name <b>Peerless</b> Type <b>Sawtooth</b> Dia. <b>5"</b> Slot/gauze <b>1/8</b> Length <b>35'</b> Set between <b>110</b> ft. and <b>130</b> ft. <b>160</b> ft. and <b>175</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>4x4</b>		
clay, Brown w/ sand streaks		30	61	11. Static water level: <b>97</b> ft. below land surface Date <b>12 Sept 78</b> mo./day/yr.		
Sand, fine to coarse - cemented		61	91	12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>100</b> g.p.m.		
Sand, cemented w/ clay streaks		91	95	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Sand, med to coarse & gravel		95	105	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <b>12</b> inches above grade		
Sand, coarse & coarse gravel		105	130	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>4</b> ft. to <b>14</b> ft.		
clay, brown		130	141	16. Nearest source of possible contamination: ft. <b>130</b> Direction <b>SW</b> Type <b>Septic</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sand, fine to coarse & fine gravel		141	180	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>STARITE</b> Model number <input type="checkbox"/> HP <b>1 1/2</b> Volts <input type="checkbox"/> Length of drop pipe <b>160</b> ft. capacity <b>30</b> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		<b>4'x4'x4" slab poured below pitless adapter</b>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Central Well &amp; Pump</b> 325 Business name License No. Address <b>181 S. Taylor Pratt</b> Signed <b>Brandon Muhl</b> Date <b>1 Nov 78</b> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5