


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Pratt	Township name	Fraction SE 1/4	Section number 21	Town number 29 S	Range number 13 W
Distance and direction from nearest town or city: 3 mi West of Sawyer Street address of well location if in city:			3 Owner of well: Matt Novotny Address: Sawyer, Kansas Well No. 1 (1-75)			
Locate with "X" in section below: N W E S 1 Mile			4 Well depth: 206 ft. Date of completion: 12/8/75 Well diameter 30 in.			
Sketch map: 			5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well			
2 Type and color of material			7 Casing: Material Stl Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. Diam. 16 in. to 146 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth			
			8 Screen: Manufacturer Doerr Type Stl Dia. 16 in. Slot/gauze 1/8 Length 60 ft. Set between 146 ft. and 206 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8 x 1/2			
Soil			9 Static water level: 86.4 ft. below land surface Date 12/8/75			
Gray & brown clay			10 Pumping level below land surfaces: No Test _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.			
Med. to coarse sand & gravel			11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
Gray clay			12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade			
Med. to coarse sand & gravel			13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay Depth: From 0 ft. to 12 ft.			
Gray clay			14 Nearest source of possible contamination: ft. 1200 Direction East Type Farm Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Med. to coarse sand & gravel			15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne Model number 12KMH HP 30 Volts _____ Length of drop pipe 140 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Red clay			16 Remarks: elevation 25363 1930 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley 29 13 21 NDX			
(use a second sheet if needed)			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name _____ License No. _____ Address Wichita, Kansas Signed _____ Date 12/8/75			