

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County PRATT	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 29	Township number T 29	Range number S R 13 W E/W
2. Distance and direction from nearest town or city: 4 W of Sawyer, Ks				3. Owner of well: LEON LOE		
Street address of well location if in city:				R.R. or street:		
				City, state, zip code: PRATT, KS		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 19 Mar 79		
<div style="text-align: center;">N</div> <div style="text-align: center;">S</div>				Well depth 100 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 80 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 258		
5. Type and color of material		From	To	10. Screen: Manufacturer's name perless		
Soil		0	3	Type Saw slot Dia. 5"		
Clay, Brown		3	6	Slot/gauze 1/8 Length 20'		
Sand, fine & clay		6	72	Set between 80 ft. and 100 ft. ft. and ft.		
Sand, fine to med & fine gravel		72	100	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 x 1/4		
				11. Static water level: 63 ft. below land surface Date 19 Mar 79		
				12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 50 g.p.m.		
				13. Water sample submitted: X Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
				16. Nearest source of possible contamination: ft. 90 Direction SE Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name FAIRBANKS MORSE Model number 1 HP 1 Volts Length of drop pipe 80 ft. capacity 25 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		4' x 4' x 4" slab poured below pitless adapter		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 325 Business name Box p32 Pratt, Ks License No. Address Pratt, Ks Signed Antonovich Date 1 Apr 79 Authorized representative		

T 29 R 13 E S 29 NE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5