

1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number		
County: Pratt		SW 1/4 SW 1/4 NW 1/4	14	T 29 S	R 14 E		
Distance and direction from nearest town or city? 1/2 N of Coats, KS			Street address of well if located within city?				
2 WATER WELL OWNER: Ed Moss							
RR#, St. Address, Box #: Coats, Kansas 67028							
City, State, ZIP Code: _____							
Board of Agriculture, Division of Water Resources Application Number: _____							
3 DEPTH OF COMPLETED WELL: 170 ft. Bore Hole Diameter: 10 in. to 170 ft., and _____ in. to _____ ft.							
Well Water to be used as:							
1 Domestic		3 Feedlot	5 Public water supply	8 Air conditioning	11 Injection well		
2 Irrigation		4 Industrial	6 Oil field water supply	9 Dewatering	12 Other (Specify below)		
7 Lawn and garden only		10 Observation well					
Well's static water level: 108 ft. below land surface measured on Dec month 8 day 79 year							
Pump Test Data: _____							
Est. Yield: 80 gpm: Well water was _____ ft. after _____ hours pumping _____ gpm							
4 TYPE OF BLANK CASING USED:							
1 Steel		3 RMP (SR)	5 Wrought iron	8 Concrete tile	Casing Joints: Glued <input checked="" type="checkbox"/> Clamped _____		
2 PVC		4 ABS	6 Asbestos-Cement	9 Other (specify below)	Welded _____		
			7 Fiberglass		Threaded _____		
Blank casing dia: 5 in. to 150 ft., Dia _____ in. to _____ ft., Dia _____ in. to _____ ft.							
Casing height above land surface: 12 in., weight _____ lbs./ft. Wall thickness or gauge No. 200							
TYPE OF SCREEN OR PERFORATION MATERIAL:							
1 Steel		3 Stainless steel	5 Fiberglass	7 PVC	10 Asbestos-cement		
2 Brass		4 Galvanized steel	6 Concrete tile	8 RMP (SR)	11 Other (specify)		
				9 ABS	12 None used (open hole)		
Screen or Perforation Openings Are:							
1 Continuous slot		3 Mill slot	5 Gauzed wrapped	8 Saw cut	11 None (open hole)		
2 Louvered shutter		4 Key punched	6 Wire wrapped	9 Drilled holes			
			7 Torch cut	10 Other (specify)			
Screen-Perforation Dia: 5 in. to _____ ft., Dia _____ in. to _____ ft., Dia _____ in. to _____ ft.							
Screen-Perforated Intervals: From 150 ft. to 170 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.							
Gravel Pack Intervals: From 14 ft. to 170 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.							
5 GROUT MATERIAL:							
1 Neat cement		2 Cement grout	3 Bentonite	4 Other			
Grouted Intervals: From 4 ft. to 14 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.							
What is the nearest source of possible contamination:							
1 Septic tank		4 Cess pool	7 Sewage lagoon	10 Fuel storage	14 Abandoned water well		
2 Sewer lines		5 Seepage pit	8 Feed yard	11 Fertilizer storage	15 Oil well/Gas well		
3 Lateral lines		6 Pit privy	9 Livestock pens	12 Insecticide storage	16 Other (specify below)		
				13 Watertight sewer lines			
Direction from well: SOUTH EAST How many feet: 150 ? Water Well Disinfected? Yes <input checked="" type="checkbox"/> No _____							
Was a chemical/bacteriological sample submitted to Department? Yes _____ No <input checked="" type="checkbox"/> If yes, date sample was submitted _____ month _____ day _____ year							
If Yes: Pump Manufacturer's name: STA RITE Model No. 5220 HP 1 Volts 230							
Depth of Pump Intake: 132 ft. Pumps Capacity rated at 25 gal./min.							
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other							
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on JAN month 9 day 80 year							
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 325							
This Water Well Record was completed on JUNE month 28 day 80 year under the business name of Central Well & Pump Inc. Pratt, Kansas by (signature) J. P. Anomich							
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
		0	2	Top soil			
		2	48	Clay, tan			
		48	105	Sand, fine to coarse and medium gravel			
		105	113	Clay, tan and gray			
		113	140	Sand, coarse and coarse gravel			
		140	165	Sand, fine to coarse and medium gravel			
		165	200	Sand, coarse and medium gravel			
ELEVATION: _____							
Depth(s) Groundwater Encountered 1. 108 ft. 2. _____ ft. 3. _____ ft. 4. _____ ft. (Use a second sheet if needed)							

OFFICE USE ONLY

T

29

R

14

E

SEC

14

SW 1/4 SW 1/4 NW 1/4