

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Pratt	Township name	Fraction SW¹/₄	Section number 17	Town number 29 S	Range number 14 W
Distance and direction from nearest town or city: 3 3/4 West of Coats Street address of well location if in city:			3 Owner of well: Melvin Schrepel Address: Coats, Kansas			
Locate with "X" in section below: <div style="text-align: center;"> </div>			Sketch map: 4 Well depth: 190 ft. Date of completion 10/74 Well diameter 30 in. 5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> _____ 7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1' Diam. 16" Weight 22 lbs./ft. ___ in. to 139 depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth			
2 Type and color of material			From	To	8 Screen:	
Soil			0	1	Manufacturer Doerr Type Steel Dia. 16" Slot/gauze 1/8 Length 52' Set between 138 ft. and 190 ft. Fittings: 138 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material ___	
Clay			1	33	9 Static water level:	
Fine to coarse sand & gravel			33	67	88 ft. below land surface Date 10/74 10 Pumping level below land surfaces: 102 ft. after 4 hrs. pumping 1000 g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 1000 g.p.m.	
Clay			67	79	11 Water sample submitted:	
Med. to coarse sand & gravel			79	143	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___	
Sandy clay			143	146	12 Well head completion:	
Med. to coarse sand & gravel			146	164	<input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
Clay			164	180	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Sandy clay with some fine sand			180	186	<input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 12 ft.	
Fine to coarse sand & fine gravel			186	190	14 Nearest source of possible contamination: None	
Sandy clay			190	193	ft. ___ Direction ___ Type ___ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
(use a second sheet if needed)					15 Pump: L & B CALIF. Not installed	
					Manufacturer's name L & B CALIF. Model number V7401349 Volts ___ Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation			17 Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name 1012 W. Harry, Wichita, Ks License No. _____ Address _____ Signed [Signature] Date 12/11/74			