

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>PRATT</b>	Fraction <b>SW 1/4 NE 1/4 NE 1/4</b>	Section number <b>18</b>	Township number <b>T 29 S</b>	Range number <b>R 14 W E/W</b>
2. Distance and direction from nearest town or city: <b>3W IN of Coats, Ks</b>			3. Owner of well: <b>PAUL SHREWER</b> R.R. or street: City, state, zip code: <b>Coats, Ks</b>			
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div>		Sketch map: <div style="text-align: center;">well X ↓ ↓ ↓ Drainage</div>		6. Bore hole dia. <b>30</b> in. Completion date <b>29 Dec 78</b> Well depth <b>173</b> ft.		
5. Type and color of material		From To		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <b>STL</b> Height: <b>Above</b> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia <b>1 1/2</b> in. to <b>133</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>188</b>		
				10. Screen: Manufacturer's name <b>W A BROWN</b> Type <input type="checkbox"/> Dia. <b>1 1/2</b> " Slot/gauze <b>48</b> Length <b>40</b> ' Set between <b>133</b> ft. and <b>173</b> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>4 X 3/8</b>		
				11. Static water level: <input type="checkbox"/> mo./day/yr. <b>95</b> ft. below land surface Date <b>29 Dec 78</b>		
				12. Pumping level below land surfaces: <b>111</b> ft. after <b>1</b> hrs. pumping <b>800</b> g.p.m. <b>115</b> ft. after <b>1</b> hrs. pumping <b>1000</b> g.p.m. Estimated maximum yield <b>1600</b> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
				16. Nearest source of possible contamination: <b>NONE</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Simmons</b> Model number <input type="checkbox"/> HP <b>100</b> Volts <input type="checkbox"/> Length of drop pipe <b>140</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Central Well &amp; Pump 325</b> Business name License No. Address <b>Box 1032 Pratt, Ks</b> Signed <b>J. H. Anomell</b> Date <b>15 Jan 79</b> Authorized representative		
				18. Elevation:		
				19. Remarks: <b>5' X 12' X 8" Concrete Slab Poured at Surface</b>		
				Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5