

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>PRATT</b>	Fraction <b>SE 1/4 NW 1/4 NE 1/4</b>	Section number <b>31</b>	Township number <b>T 29 S</b>	Range number <b>R 14 W E/W</b>
2. Distance and direction from nearest town or city: <b>3W 25 1/4</b>			3. Owner of well: <b>ROBERT HOWELL</b>			
Street address of well location if in city: <b>Coats, KS</b>			City, state, zip code: <b>PRATT, KS</b>			
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. <b>30</b> in. Completion date _____ Well depth <b>165</b> ft. <b>26 DEC 78</b>	
					7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material			From	To	8. Use: Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____	
Soil			0	2	9. Casing: Material <b>STL</b> Height: <b>Above</b> or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. <b>1 1/2</b> in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <b>188</b>	
Clay, Brown & white			2	32	10. Screen: Manufacturer's name <b>COOK &amp; WABROWN</b> Type _____ Dia. <b>1 1/2</b> in. Slot/gauze <b>1/8</b> Length <b>40'</b> Set between <b>125</b> ft. and <b>145</b> <b>COOK</b> ft. <b>145</b> ft. and <b>165</b> <b>BROWN</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/4 X 3/8</b>	
Sand, fine to coarse & med gravel			32	60	11. Static water level: _____ mo./day/yr. <b>101</b> ft. below land surface Date <b>26 DEC 78</b>	
Clay, Tan			60	72	12. Pumping level below land surfaces: <b>119</b> ft. after <b>1</b> hrs. pumping <b>800</b> g.p.m. <b>122</b> ft. after <b>1</b> hrs. pumping <b>900</b> g.p.m. Estimated maximum yield <b>1200</b> g.p.m.	
Sand, fine to coarse & med gravel			72	92	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____	
Clay, Tan & white			92	100	14. Well head completion: Pitless adapter <b>12</b> inches above grade	
Sand, fine to coarse & med to coarse gravel			100	135	15. Well grouted? <input checked="" type="checkbox"/> With: Neat cement <input checked="" type="checkbox"/> Bentonite _____ Concrete _____ Depth: From <b>0</b> ft. to <b>10</b> ft.	
Sand, fine to coarse & fine gravel			135	155	16. Nearest source of possible contamination: <b>NONE</b> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____	
Clay, Green & tan w/numerous sand streaks			155	174	17. Pump: _____ Not installed Manufacturer's name <b>SUMANS</b> Model number _____ HP <b>80</b> Volts _____ Length of drop pipe <b>140</b> ft. capacity <b>800</b> g.p.m. Type: _____ Submersible _____ <input checked="" type="checkbox"/> Turbine _____ _____ Jet _____ Reciprocating _____ _____ Centrifugal _____ Other _____	
Sand, very fine to fine w/clay			174	188	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Central Well &amp; Pump</b> <b>325</b> Business name _____ License No. _____ Address <b>Box 1032 PRATT, KS</b> Signed <b>John H. H. H. H.</b> Date <b>15 Jan 79</b> Authorized representative	
Shale, Red			188	195		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: <b>315 ft</b> <b>8' X 16' X 8" Concrete slab</b> <b>poured at surface</b> <b>29 14 31 NAX</b>				
Topography: Hill _____ Slope _____ <input checked="" type="checkbox"/> Upland Valley _____						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5