

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County KIOWA Fraction NW 1/4 SE 1/4 SW 1/4 Section number 1 Township number T 29 Range number S R 16 W E/W	
2. Distance and direction from nearest town or city: 3 N 2 W Street address of well location if in city: Crest, KS	
3. Owner of well: JERALD STARKEY R.R. or street: City, state, zip code: RUSSELL, KS	
4. Locate with "X" in section below: Sketch map: <div style="display: flex; align-items: center;"> <div style="text-align: center;"> </div> <div style="margin-left: 20px;"> <p style="text-align: center;">Well X ↓ ↓ DRAWINGS</p> </div> </div>	
6. Bore hole dia. 30 in. Completion date 1 Feb 79 Well depth 130 ft.	
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material STL Height (Above) or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 90 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188	
10. Screen: Manufacturer's name WA BROWN Type <input type="checkbox"/> Dia. 16" Slot/gauze 1/8 Length 40' Set between 90 ft. and 130 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 3/8	
11. Static water level: 44 ft. below land surface Date 1 Feb 79 mo./day/yr.	
12. Pumping level below land surfaces: 57 ft. after 1 hrs. pumping 800 g.p.m. 60 ft. after 1 hrs. pumping 1000 g.p.m. Estimated maximum yield 1700 g.p.m.	
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.	
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
16. Nearest source of possible contamination: NONE ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name SIMMONS Model number <input type="checkbox"/> HP 60 Volts <input type="checkbox"/> Length of drop pipe 80 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 5'x10'x8" Concrete Slab poured at surface
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 325 License No. Address Box 1032 Pratt, KS Signed L. D. Anonmichl Date 15 Feb 79 Authorized representative	

T 29
 R 16 W
 Sec 1
 NW SE SW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5