

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 14	Township number T 29 S	Range number R 18 W
2. Distance and direction from nearest town or city: 2 1/2 S Greensburg Street address of well location if in city: Kansas			3. Owner of well: Wayne Holderman R.R. or street: City, state, zip code: Greensburg Kansas			
4. Locate with "X" in section below:		Sketch map:		<input checked="" type="checkbox"/> Bore hole dia. 5 1/8 in. Completion date Well depth 137 ft. 6-11-75 7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material PI Height: Above or below Threaded <input type="checkbox"/> Welded GI Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 137 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 200		
5. Type and color of material				From	To	X Screen: Manufacturer's name Sunflow Plastics Type RMP Dia. 5" Slot gauge 1/8 Length 20' Set between 117 ft. and 137 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 20-30
Top Soil				0	2	11. Static water level: _____ no./day/yr 82 ft. below land surface Date 6-11-75
Bk. Clay				2	9	12. Pumping level below land surfaces: 82 ft. after 1 hrs. pumping 3 g.p.m. ____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.
Tan Clay with Gyp				9	28	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Tan Clay				28	79	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
Gravel				79	94	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Tan Clay				94	125	16. Nearest source of possible contamination: ft. 50 Direction W Type Corral Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Gravel				125	137	17. Pump: _____ Not installed Manufacturer's name Windmill Model number _____ HP _____ Volts _____ Length of drop pipe 105 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carl Kayse Water Well Sew. 224 Business name _____ License No. _____ 603 So. Maple Greensburg Kan. Address _____ Signed Carl Kayse 6-11-75 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 29 S
 R 18 W
 Sec 14
 NE 1/4 NE 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5