


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction SE 1/4 NE 1/4 SE1/4	Section number 31	Township number T 29 S	Range number R 19 XX/W
2. Distance and direction from nearest town or city: 8 miles S. & 2 E of Mullinville Street address of well location if in city:				3. Owner of well: Norval Ralston R.R. or street: City, state, zip code: Mullinville, Kansas 67109		
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 9 7/8 in. Completion date _____ Well depth 185 ft. 6-14-79		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above XXXX Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 185 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 265		
				10. Screen: Manufacturer's name _____ Pumpco Type PVC Dia. 5" Slot/gauze fine Length 40' Set between 145 ft. and 185 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material #1 fine		
Top Soil				From	To	11. Static water level: _____ mo./day/yr. 122 ft. below land surface Date 6-4-79
Clay				8	60	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.
Sandy Clay-some limestone				60	98	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Med. to Lar. Sand				98	125	14. Well head completion: <input type="checkbox"/> Pitless adapter 18 Inches above grade
Sandy Clay-fine to medium sand				125	180	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Black Shale				180	185	16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
(Use a second sheet if needed)				17. Pump: _____ Not installed Manufacturer's name Customers Windmill Model number _____ HP _____ Volts _____ Length of drop pipe 157 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name License No. Address Meade, Kansas 67864 Signed _____ Date 11-26-79 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

29
 19
 31
 SE
 NESE
 1/4
 1/4
 6/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5