

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction SE 1/4 SW 1/4 NW 1/4	Section number 33	Township number T 29 S R 19	Range number 19
2. Distance and direction from nearest town or city: Street address of well location if in city: 3 1/2 E 75 of Mullinville Kansas			3. Owner of well: Esther Hayse R.R. or street: Mullinville Kansas City, state, zip code: 67109			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 5 1/2 in. Completion date 3-12-76 Well depth 223 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material RMP Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 223 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
				10. Screen: Manufacturer's name Jess and Lowell Type RMP Dia. 5" Slot/ 1/8" Length 30' Set between 193 ft. and 223 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4-3/8		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 181 ft. below land surface Date 3-2-76		
				12. Pumping level below land surfaces: 181 ft. after 1 hrs. pumping 3 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 10 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date 3-12-76		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 14 inches above grade		
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 1 ft. to 11 ft.		
				16. Nearest source of possible contamination: ft. 100 Direction E Type BURN Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Monitor Model number 2A HP 1 Voltage 220 Length of drop pipe 200 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input checked="" type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carl Hayse Water Well 224 Business name 603 So Maple GREENSBURG License No. 5 Address Carl Hayse Kan Signed Carl Hayse Date 3-12-76 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 29 R 19 S 33 Sec 33

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5