

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction 1/4 SE 1/4 SE 1/4	Section number 18	Township number T 29 S R	Range number 2W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Name or street: City, state, zip code:		
			Dwight R. Johnson 121 South Green Clearwater, Kansas		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. <u>11</u> in. Completion date _____ Well depth <u>60</u> ft. <u>2-4-78</u>		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>styrene</u> Weight: Above or below _____ Threaded _____ Welded <u>gl</u> Surface _____ <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>60</u> ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. <u>200</u>		
Topsoil			10. Screen: Manufacturer's name _____ Sunflower Plastic		
Clay			Type <u>styrene</u> Dia. <u>5"</u> Slot/gauge <u>1/16</u> .06 Length <u>43'</u> Set between <u>17</u> ft. and <u>60</u> ft. _____ ft. and _____ ft.		
Fine Sand			Gravel pack? <input checked="" type="checkbox"/> <u>yes</u> Size range of material <u>1/4-1/8"</u>		
Grey Shale			11. Static water level: _____ mo./day/yr. <u>15</u> ft. below land surface Date <u>2-4-78</u>		
			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter _____ <u>12</u> inches <u>capped</u> above grade		
			15. Well grouted? <input checked="" type="checkbox"/> <u>yes 1-2 fine sand mix</u> With: _____ Neat cement _____ <u>14</u> Bentonite <input checked="" type="checkbox"/> Concrete _____ Depth: From _____ ft. to _____ ft.		
			16. Nearest source of possible contamination: <u>NONE</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> <u>X</u> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> <u>X</u> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: Flat Ground Septic system not installed at this time. No apparent source for contamination.			
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. _____ Address _____ Signed <u>M. Arnold</u> Date <u>3-14-78</u> Authorized representative <u>3-14-78</u>			

T 29 S R 2W E
 Sec 18
 SESE
 1/4 1/4 1/4