

1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number			
County: JEDGWICK		SW 1/4 SE 1/4 SE 1/4	23	T 29 S	R 2 NW			
Distance and direction from nearest town or city?			Street address of well if located within city?					
			700 ELAINE					
2 WATER WELL OWNER: BOB HARRINGTON								
RR#, St. Address, Box # : 700 ELAINE								
City, State, ZIP Code : CLEARWATER KANSAS 67026								
Board of Agriculture, Division of Water Resources Application Number:								
3 DEPTH OF COMPLETED WELL: 47 1/2 ft. Bore Hole Diameter: 5 in. to 47 1/2 ft. and . . . in. to . . . ft.								
Well Water to be used as:								
1 Domestic		3 Feedlot	5 Public water supply	8 Air conditioning	11 Injection well			
2 Irrigation		4 Industrial	6 Oil field water supply	9 Dewatering	12 Other (Specify below)			
		7 Lawn and garden only	10 Observation well					
Well's static water level X 30 ft. below land surface measured on . . . month . . . day . . . year								
Pump Test Data : Well water was . . . ft. after . . . hours pumping . . . gpm								
Est. Yield . . . gpm: Well water was . . . ft. after . . . hours pumping . . . gpm								
4 TYPE OF BLANK CASING USED:								
1 Steel		3 RMP (SR)	5 Wrought iron	8 Concrete tile	Casing Joints: Glued . . . Clamped . . .			
2 PVC		4 ABS	6 Asbestos-Cement	9 Other (specify below)	Welded . . .			
			7 Fiberglass		Threaded . . .			
Blank casing dia . . . 5 in. to . . . 37 1/2 ft. Dia . . . in. to . . . ft. Dia . . . in. to . . . ft.								
Casing height above land surface . . . 18 1/2 in., weight . . . 236.8 lbs./ft. Wall thickness or gauge No. 214								
TYPE OF SCREEN OR PERFORATION MATERIAL:								
1 Steel		3 Stainless steel	5 Fiberglass	8 RMP (SR)	10 Asbestos-cement			
2 Brass		4 Galvanized steel	6 Concrete tile	9 ABS	11 Other (specify)			
					12 None used (open hole)			
Screen or Perforation Openings Are:								
1 Continuous slot		3 Mill slot	5 Gauzed wrapped	8 Saw cut	11 None (open hole)			
2 Louvered shutter		4 Key punched	6 Wire wrapped	9 Drilled holes				
			7 Torch cut	10 Other (specify)				
Screen-Perforation Dia . . . 5 in. to . . . ft. Dia . . . in. to . . . ft. Dia . . . in. to . . . ft.								
Screen-Perforated Intervals: From . . . 37 1/2 ft. to . . . 47 1/2 ft. From . . . ft. to . . . ft. From . . . ft. to . . . ft.								
Gravel Pack Intervals: From . . . 30 ft. to . . . 47 1/2 ft. From . . . ft. to . . . ft. From . . . ft. to . . . ft.								
5 GROUT MATERIAL:								
1 Neat cement		2 Cement grout	3 Bentonite	4 Other				
Grouted Intervals: From X 0 ft. to X 10 ft. From . . . ft. to . . . ft. From . . . ft. to . . . ft.								
What is the nearest source of possible contamination:								
1 Septic tank		4 Cess pool	7 Sewage lagoon	10 Fuel storage	14 Abandoned water well			
2 Sewer lines		5 Seepage pit	8 Feed yard	11 Fertilizer storage	15 Oil well/Gas well			
3 Lateral lines		6 Pit privy	9 Livestock pens	12 Insecticide storage	16 Other (specify below)			
Direction from well . . . EAST . . . How many feet . . . 12 . . . ? Water Well Disinfected? Yes X No								
Was a chemical/bacteriological sample submitted to Department? Yes . . . No X . . . If yes, date sample was submitted . . . month . . . day . . . year: Pump Installed? Yes . . . No X . . .								
If Yes: Pump Manufacturer's name . . . Model No. . . . HP . . . Volts . . .								
Depth of Pump Intake . . . ft. Pumps Capacity rated at . . . gal./min.								
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other								
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on . . . 3 month . . . 26 day . . . 82 year								
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 402								
This Water Well Record was completed on . . . 3 month . . . 26 day . . . 82 year under the business name of MEMILLAN WATER WELL DRILLING by (signature) Glenn M. Miller								
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:								
		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG	
		0	3	SANDY LOAN				
		3	22	Red CLAY				
		22	24	blue CLAY				
		24	34	FINE SAND				
		34	35	CLAY				
35	47 1/2	COURSE SAND						
ELEVATION:								
Depth(s) Groundwater Encountered 1. . . ft. 2. . . ft. 3. . . ft. 4. . . ft. (Use a second sheet if needed)								

OFFICE USE ONLY

T

29

R

2

E

2

SEC.

3

SW 1/4

SE 1/4

SE 1/4

SE 1/4

SE 1/4

SE 1/4

SE 1/4

SE 1/4

SE 1/4

SE 1/4

SE 1/4

SE 1/4