

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82g-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Sedgwick</b>	Fraction <b>1/4 NE 1/4 NE 1/4</b>	Section number <b>26</b>	Township number <b>T 29 S</b>	Range number <b>R 2W E/W</b>
2. Distance and direction from nearest town or city: <b>360 South 3rd</b> Street address of well location if in city: <b>Clearwater, Kansas</b>				3. Owner of well: <b>Kenneth Coy</b> R.R. or street: <b>360 South 3rd</b> City, state, zip code: <b>Clearwater, Kansas</b>		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>11</u> in. Completion date <u>5-4-77</u> Well depth <u>40</u> ft.	
					7. <u>X</u> Cable tool <u>X</u> Rotary <u>  </u> Driven <u>  </u> Dug <u>  </u> Hollow rod <u>  </u> Jetted <u>  </u> Bored <u>  </u> Reverse rotary	
5. Type and color of material					8. Use: <u>  </u> Domestic <u>  </u> Public supply <u>  </u> Industry <u>  </u> Irrigation <u>  </u> Air conditioning <u>  </u> Stock <u>X</u> Lawn <u>  </u> Oil field water <u>  </u> Other	
Topsoil		From 0 To 3			9. Casing: Material <u>Styrene</u> Height: Above or below <u>1111</u> Threaded <u>  </u> Welded <u>81</u> Surface <u>12</u> in. RMP <u>X</u> PVC <u>  </u> Weight <u>  </u> lbs./ft. Dia. <u>5</u> in. to <u>40</u> ft. depth Wall Thickness: inches or Dia. <u>  </u> in. to <u>  </u> ft. depth Gauge No. <u>200</u>	
Clay		From 3 To 13			10. Screen: Manufacturer's name <u>Sunflower Plastic</u> Type <u>styrene</u> Dia. <u>5"</u> Slot/gauge <u>.06</u> Length <u>10'</u> Set between <u>30</u> ft. and <u>40</u> ft. <u>  </u> ft. and <u>  </u> ft.	
Fine Sand		From 13 To 40			Gravel pack? <u>yes</u> Size range of material <u>1/2-1/8"</u>	
					11. Static water level: <u>  </u> mo./day/yr. <u>25</u> ft. below land surface Date <u>5-4-77</u>	
					12. Pumping level below land surfaces: <u>  </u> ft. after <u>  </u> hrs. pumping <u>  </u> g.p.m. <u>  </u> ft. after <u>  </u> hrs. pumping <u>  </u> g.p.m. Estimated maximum yield <u>  </u> g.p.m.	
					13. Water sample submitted: <u>  </u> mo./day/yr. <u>  </u> Yes <u>  </u> No Date <u>  </u>	
					14. Well head completion: <u>Capped</u> <u>  </u> Pitless adapter <u>12</u> Inches above grade	
					15. Well grouted? <u>yes</u> With: <u>  </u> Neat cement <u>  </u> Bentonite <u>X</u> Concrete Depth: From <u>40"</u> ft. to <u>14</u> ft.	
					16. Nearest source of possible contamination: <u>NONE</u> ft. <u>  </u> Direction <u>  </u> Type <u>  </u> Well disinfected upon completion? <u>X</u> Yes <u>  </u> No	
					17. Pump: <u>X</u> Not installed Manufacturer's name <u>  </u> Model number <u>  </u> HP <u>  </u> Volts <u>  </u> Length of drop pipe <u>  </u> ft. capacity <u>  </u> g.p.m. Type: <u>  </u> Submersible <u>  </u> Turbine <u>  </u> Jet <u>  </u> Reciprocating <u>  </u> Centrifugal <u>  </u> Other	
18. Elevation:		19. Remarks: <b>Septic System was not installed when the well was drilled.</b>  <b>No apparent source for contamination.</b>			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Harp Well &amp; Pump</b> <b>236</b> Business name License No. Address <b>Wichita, Kansas</b> Signed <u>M. Arnold</u> Date <u>5-10-77</u> Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5