



*The Professionals*

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Paul Hayse  
Kiowa County  
7-15-88

Location: NE $\frac{1}{4}$  1-29-20  
2 So. & 1-3/4 E. of Mullinville, Ks.  
80' E. of old well

Static Water Level - 129'

Test #1

0	5	Top soil
5	20	Brown sandy clay - loose
20	35	Brown sandy clay - loose
35	50	Brown sandy clay - loose
50	65	Brown sandy clay - loose
65	80	Brown sandy clay - loose
80	95	Brown sandy clay - loose
95	100	Brown sandy clay - loose
100	110	FMC sand & gravel - loose
110	125	FMC sand & gravel - loose
125	140	FMC sand & gravel - hard streak
140	145	FMC sand & gravel - loose
145	170	Cemented sand, limestone, brown rock Very hard
170	185	Fine to medium sand - tight
185	205	FMC sand & gravel - loose
205	225	Shale - loose