


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction SW 1/4 NW 1/4 NW 1/4	Section number 34	Township number T 29 S R 20 E/W	Range number 20 E/W
2. Distance and direction from nearest town or city: 0 1/2 S., 1 West of Mullinville, Ks. Street address of well location if in city:			3. Owner of well: Steve Kirk R.R. or street: Mullinville, Kansas 67109 City, state, zip code:			
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map:		6. Bore hole dia. 9 7/8 in. Completion date _____ Well depth 170 ft. 4-15-76	
5. Type and color of material			From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Top soil			0	5	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Tan clay with traces of limestone			5	105	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 291 lbs./ft. 100 Dia. 5 in. to 170 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 265	
Med. to lar. sand			105	110	10. Screen: Manufacturer's name _____ Jess & Lowell Type PVC Dia. 5" Slot/gauze 1/8" Length 50' Set between 120 ft. and 170 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 3/16"	
Tan clay and limestone			110	127	11. Static water level: _____ mo./day/yr. 127 ft. below land surface Date 4/6/76	
Med. to lar. sand			127	172	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10-15 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 18 Inches above grade	
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: none ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: Manufacturer's name Set up his used Not installed Windmill _____ Model number _____ hp _____ Volts _____ Length of drop pipe 147 ft. capacity 2 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input checked="" type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name License No. Address Meade, Kansas 67864 Signed John L. Friesen Date 4-30-76 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

29
 20
 34
 Sec
 1/4
 1/4
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5