


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction SE 1/4 SW 1/4 SE 1/4	Section number 22	Township number T 29 S R 21 W	Range number 21 W																								
2. Distance and direction from nearest town or city: 3.32 E Bucklin Street address of well location if in city: Kansas				3. Owner of well: N.L. Christopher R.R. or street: City, state, zip code: Bucklin Kansas																										
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W 1 Mile E S 1 Mile</div> 				Sketch map: 6. Bore hole dia. 8 3/4 in. Completion date Well depth 195 ft. 7-3-78																										
5. Type and color of material				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																										
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																										
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td></td> <td>From</td> <td>To</td> </tr> <tr> <td>Top Soil</td> <td>0</td> <td>3</td> </tr> <tr> <td>lt. Brown Clay</td> <td>3</td> <td>14</td> </tr> <tr> <td>Gyp + Clay</td> <td>14</td> <td>19</td> </tr> <tr> <td>lt. Brown Clay</td> <td>19</td> <td>132</td> </tr> <tr> <td>Sand</td> <td>132</td> <td>161</td> </tr> <tr> <td>Brown Clay</td> <td>161</td> <td>167</td> </tr> <tr> <td>GRAVEL</td> <td>167</td> <td>195</td> </tr> </table>					From	To	Top Soil	0	3	lt. Brown Clay	3	14	Gyp + Clay	14	19	lt. Brown Clay	19	132	Sand	132	161	Brown Clay	161	167	GRAVEL	167	195	9. Casing: Material PI Height: Above or below Threaded <input type="checkbox"/> Welded GI Surface 16 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 195 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200		
					From	To																								
Top Soil	0	3																												
lt. Brown Clay	3	14																												
Gyp + Clay	14	19																												
lt. Brown Clay	19	132																												
Sand	132	161																												
Brown Clay	161	167																												
GRAVEL	167	195																												
				10. Screen: Manufacturer's name Sunflower Plastic Type RMP Dia. 5" Slot/gauze 1/8 Length 20 Set between 175 ft. and 195 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 X 3/4																										
				11. Static water level: <input type="checkbox"/> mo./day/yr. 132 ft. below land surface Date 7-3-78																										
				12. Pumping level below land surfaces: 132 ft. after 1 hrs. pumping 3 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 15 g.p.m.																										
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date																										
				14. Well head completion: 16 <input type="checkbox"/> Pitless adapter 16 Inches above grade																										
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.																										
				16. Nearest source of possible contamination: ft. 1625 Direction Stock Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																										
				17. Pump: Windmill Not installed Manufacturer's name Windmill HP <input type="checkbox"/> Volts <input type="checkbox"/> Model number <input type="checkbox"/> Length of drop pipe 168 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																										
(Use a second sheet if needed)																														
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CARL HAYSE WATER WELL SERV. 224 Business name 603 S. Maple, Greensburg, Kans. License No. 2-3-78 Address Carl Hayse Signed Carl Hayse Authorized representative Date 7-3-78																										
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley																														

29 210 22 SE SW SE