


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County: FORD		Fraction: SE 1/4 SE 1/4 NE 1/4		Section number: 24		Township number: T 29		Range number: R 21		(W)	
2. Distance and direction from nearest town or city: 2 1/2 S 4 E Bucklin Kansas				3. Owner of well: VERN BIRNEY R.R. or street: City, state, zip code: Bucklin Kansas							
4. Locate with "X" in section below: <div style="text-align: center;">  </div>				Sketch map:				6. Bore hole dig. 8 3/4 in. Completion date 7-29-77 Well depth 183 ft.			
5. Type and color of material				From		To		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
								8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
								9. Casing: Material GI Height: Above or below Threaded <input type="checkbox"/> Welded PI Surface 14 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.5 lbs./ft. Dia. 5 in. 183 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 200			
								10. Screens: Manufacturer's name Sunflower Plastics Type RMP Dia. 5" Slot/ gauze 1/8 Length 20' Set between 163 ft. and 183 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4" to 1/2"			
Top Soil				0		3		11. Static water level: 169 ft. below land surface Date 7-29-77			
Tan Clay				3		27		12. Pumping level below land surfaces: 169 ft. after 1 hrs. pumping 3 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 5 g.p.m.			
DK. Br. Clay				27		35		13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
Tan Clay				35		123		14. Well head completion: 14 inches above grade <input type="checkbox"/> Pitless adapter			
" " with coarse Gravel				123		137		15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
Gravel				137		183		16. Nearest source of possible contamination: Live Stock Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
								17. Pump: 1 1/2 hp <input type="checkbox"/> Not installed Manufacturer's name Ward mill Volts <input type="checkbox"/> Model number HP Length of drop pipe 125 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
								18. Elevation:			
								19. Remarks:			
								20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CARL HAYSE WATER WELL SERV. 224 Business name 603 S. Maple, Greensburg, Kans. License No. 71291 Address Carl Hayse Date 7/29/77 Signed <input type="checkbox"/> Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

29 ^T	21 ^R	24 ^{Sec}	SESENE
			1/4 1/4 1/4