

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Ford	Fraction <i>SW 1/4 NW 1/4 SW 1/4</i>	Section number 2	Township number T 29 S R 22 E/W	Range number
2. Distance and direction from nearest town or city: 3 mi West -.4 north Bucklin			3. Owner of well: Leon Boor R.R. or street: % Casterline Irrigation City, state, zip code: Dodge City, Kansas		
4. Locate with "X" in section below: <div style="text-align: center; margin-top: 10px;"> <p style="font-size: small; text-align: center;">N W E S 1 Mile</p> </div>			Sketch map:		
5. Type and color of material			6. Bore hole dia. 28 in. Completion date _____ Well depth 182 ft. 8-11-77		
			7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: Domestic ___ Public supply ___ Industry ___ <input checked="" type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other ___		
			9. Casing: Material metal Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP ___ PVC ___ Weight 31.66 lbs./ft. Dia. 16 in. to 182 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. .188		
			10. Screen: Manufacturer's name Cook & W.A. Brown Type 35% Cook, 17% Br. Dia. 16 Slot/gauze 1/8 Length 80 Set between 102 ft. and 182 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/2 down		
			11. Static water level: _____ mo./day/yr. 112 ft. below land surface Date 8-11-77		
			12. Pumping level below land surfaces: 170 ft. after 2 hrs. pumping 800 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 800 g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No ___ Date _____		
			14. Well head completion: Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
			15. Well grouted? yes With: Neat cement ___ Bentonite <input checked="" type="checkbox"/> Concrete ___ Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: field ft. _____ Direction _____ Type _____ Well disinfected upon completion? Yes ___ No <input checked="" type="checkbox"/>		
			17. Pump: Not installed Manufacturer's name Goulds Model number 10JHC HP 80 Volts _____ Length of drop pipe 160 ft. capacity 650 g.p.m. Type: _____ Submersible _____ <input checked="" type="checkbox"/> Turbine Jet _____ Reciprocating Centrifugal _____ Other _____		
18. Elevation:			19. Remarks:		
Topography: Hill _____ Slope _____ <input checked="" type="checkbox"/> Upland Valley _____			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name License No. _____ Address Dodge City, Ks Signed Bell G. J. Trab Date 9-7- Authorized representative		
			(Use a second sheet if needed)		