



1. Location of well: <u>FCRD</u>		County <u>NE 1/4 CENTER 1/4</u>		Section number <u>9</u>		Township number <u>T 29 S</u>		Range number <u>R 22 E</u>	
2. Distance and direction from nearest town or city: <u>1 3/4 mi. EAST</u> Street address of well location if in city: <u>3/4 mi. North-Kingsdown</u>				3. Owner of well: <u>Charles Williams</u> R.R. or street: <u>50 CHERRYBROOK RD.</u> City, state, zip code: <u>WESTON, MASS. 02193</u>					
4. Locate with "X" in section below:  Sketch map: 				6. Bore hole dia <u>7 1/2</u> in. Completion date <u>Aug 18</u> Well depth <u>180</u> ft.					
5. Type and color of material				From		To		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
								8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
TOP SOIL				0		10		9. Casing: Material <u>IRON</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>34</u> lbs./ft. Dia. <u>1 1/2</u> in. to <u>180</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth Gauge No. <u>188</u>	
								10. Screen: Manufacturer's name <u>DAERR METAL</u> Type <u>IRON</u> Dia. <u>1 1/2</u> Slot/gauze <u>3/16</u> Length <u>60</u> Set between <u>120</u> ft. and <u>180</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>4/4 x 5/8</u>	
CLAY				10		100		11. Static water level: <u>100</u> ft. below land surface Date <u>Aug 18, 76</u>	
								12. Pumping level below land surfaces: <u>100</u> ft. after <u>3</u> hrs. pumping <u>1000</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1000-1200</u> g.p.m.	
GRAVEL + SAND				100		180		13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <input checked="" type="checkbox"/> No <u> </u> Date <u> </u>	
								14. Well head completion: <u> </u> Pitless adapter <u>12</u> inches above grade	
								15. Well grouted? <input checked="" type="checkbox"/> YES With: <u> </u> Neat cement <u> </u> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
								16. Nearest source of possible contamination: ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <u> </u> Yes <u> </u> No	
								17. Pump: <u> </u> Not installed Manufacturer's name <u>FAIRBANKS-MORSE</u> Model number <u>7000</u> HP <u>100</u> Volts <u> </u> Length of drop pipe <u>170</u> ft. capacity <u>1200</u> g.p.m. Type: <u> </u> Submersible <input checked="" type="checkbox"/> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other	
								18. Elevation: <u>FLAT</u> Topography: <u> </u> Hill <u> </u> Slope <u> </u> Upland <u> </u> Valley	
19. Remarks: <u> </u>				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>BAAM DRILLING 217</u> Business name <u> </u> License No. <u> </u> Address <u>Bucklin</u> Signed <u>RWBRAU</u> Date <u>8-27</u> Authorized representative					