


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

29 22 W 18 S NE 1/4
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County FORD	Township name SOOVILLE	Fraction SE 1/4 NE 1/4 NE 1/4	Section number 18	Town number 29	Range number 22 W
Distance and direction from nearest town or city: IN Kingsdown				3 Owner of well: TROY DAVIS			
Street address of well location if in city:				Address: Kingsdown, KS			
Locate with "X" in section below:		Sketch map:		4 Well depth: 215 ft. Date of completion 11 Oct 75 Well diameter 8 in.			
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>			
				7 Casing: Material PVC Height: above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 20 in. wall Diam. 6 1/2 in. Weight 25 lb./ft. 5 in. to 215 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 5 in. to 215 ft. depth			
2		Type and color of material		From	To	8 Screen:	
		Soil		0	3	Manufacturer Jess Lowell	
		CLAY		3	95	Type PVC Dia. 5	
		Rock		95	102	Slot gauge 1 1/16 Length 3	
		CLAY		102	165	Set between 185 ft. and 215 ft.	
		SAND		165	185	Fittings:	
		GRAVEL		185	213	Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8	
		Rock		213	215	9 Static water level:	
						125 ft. below land surface Date 11 Oct 75	
						10 Pumping level below land surfaces: N/A	
						____ ft. after ____ hrs. pumping ____ g.p.m.	
						____ ft. after ____ hrs. pumping ____ g.p.m.	
						Estimated maximum yield ____ g.p.m.	
						11 Water sample submitted:	
						<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
						12 Well head completion:	
						<input checked="" type="checkbox"/> Pitless adapter 20 inches above grade	
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						<input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/>	
						Depth: From 3 ft. to 13 ft.	
						14 Nearest source of possible contamination:	
						ft. 150 Direction South Type sewer	
						Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						15 Pump:	
						<input type="checkbox"/> Not installed	
						Manufacturer's name Reda	
						Model number 1401000 HP 1 1/2 Volts 220	
						Length of drop pipe 129 ft. capacity 1000 g.p.m.	
						Type:	
						<input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine	
						<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
						<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation		(use a second sheet if needed)		17 Water well contractor's certification:			
Topography:				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
<input checked="" type="checkbox"/> Hill				Cragg Drilling 111			
<input type="checkbox"/> Slope				Business name			
<input type="checkbox"/> Upland				Address Rt 1 Deck			
<input type="checkbox"/> Valley				Signed Ray Plugs Date 11 Oct 75			
				Authorized representative			