


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

NE?

1. Location of well:	County Ford	Fraction 25' South east of center $\frac{1}{4}$ $\frac{1}{4}$	Section number 34	Township number T 29 S R 22 E/W	Range number		
2. Distance and direction from nearest town or city: 1 1/4 south-3 east-1 1/4 south & 1/4 west Street address of well location if in city: of Kingsdown, Ks			3. Owner of well: Mrs. Bernard Beeber-Kregar R.R. or street: Box 63 City, state, zip code: Offerle, Kansas				
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. 20 in. Completion date _____ Well depth 200 ft. 11-4-76			
5. Type and color of material		From	To	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
		Surface		0	3	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
		Brown clay		3	47	9. Casing: Material Metals Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.66 lbs./ft.	
		Fine sand		47	65	Dia. 16 in. to 200 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. 188	
		Brown clay		65	81	10. Screen: Manufacturer's name _____ W.A. Brown Type 10% Free-flow Dia. 16 Slot/gauze 1/8 Length 120 Set between _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/2 down	
Med. sand and gravel		81	90	11. Static water level: _____ mo./day/yr. _____ ft. below land surface Date _____			
Brown clay with 30-35% fine sand		90	120	12. Pumping level below land surfaces: 145 ft. after 1 hrs. pumping 650 g.p.m. 155 ft. after 1 hrs. pumping 800 g.p.m. Estimated maximum yield 1200 g.p.m.			
Fine sand and sandrock with 30% clay		120	137	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date _____			
Sandy brown clay		137	141	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> _____ Inches above grade			
Good loose half med. sand and gravel		141	180	15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
Good med. sand and gravel		180	195	16. Nearest source of possible contamination: NA ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Yellow clay and blue shale		195	200	17. Pump: _____ Not installed Manufacturer's name Goulds Model number 12 JIC HP 80 Volts _____ Length of drop pipe 185 ft. capacity 650 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)							
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name Dodge City, Kansas License No. _____ Address _____ Signed Carl C. Little Date 11-20 Authorized representative				

Topography:
☐ Hill
☐ Slope
☒ Upland
☐ Valley

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5