


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County FOND	Fraction Center NE	Section number 36	Township number T 29 S	Range number R 22 W
2. Distance and direction from nearest town or city: Street address of well location if in city:		4 1/2 S - 2 1/2 W OF BUCKLIN KS		3. Owner of well: R.R. or street: City, state, zip code:		
				BAILEY BROS. WICHITA KS		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 30 in. Completion date Well depth 245 ft. 8-3-79		
5. Type and color of material		From		To		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
top soil		0		3		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sandy clay		96		100		9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12" in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.
COLECH & sandy clay		100		122		Dia. 16 in. to 24 1/2 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219
Sand & gravel		122		242		10. Screen: Manufacturer's name DOERR Type STEEL Dia. 16" Slot/gauze 1/4 Length 60 Set between 185 ft. and 245 ft. ft. and <input type="checkbox"/> ft.
Shale		242		245		Gravel pack? Yes Size range of material 4x5/8
						11. Static water level: <input type="checkbox"/> mo./day/yr. 131 ft. below land surface Date 8-3-79
						12. Pumping level below land surfaces: 131 ft. after 1 hrs. pumping 750 g.p.m. ft. after <input type="checkbox"/> hrs. pumping 750 g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.
						13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction NONE Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: GOULD <input type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number 1mo HP 125 volts <input type="checkbox"/> Length of drop pipe 240 ft. capacity 750 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BRAUN DILLING 217 Business name Bucklin KS License No. <input type="checkbox"/> Address RUBEN Date 9-5-79 Signed BRAUN Authorized representative		