WATER WELL RECORD Form WWC-5 KSA 82a-1212

| WATER WELL RECORD Form WMC-5 KSA 82a-1212 |
|--|
| 1 LOCATION OF WATER WELL: Fraction Section Number Township Number Range Number COUNTY: FORD NW 1/4 SE 1/4 NE 1/4 13 7 29 S R 22 W |
| Distance and direction from nearest town or city street address of well if located within city? FROM BUCKLIN - 1 1/2 WEST ON HIGHWAY 54 - 1 1/4 SOUTH |
| 2 WATER WELL OWNER: STIMPERT, BARRY RR#, St. Address, Box # : 12989 WINDY ROAD Board of Agriculture, Division of Water Resources City, State, ZIP code : BUCKLIN, KS 67835- Application Number: 3 LOCATE WELL'S LOCATION WITH ! 4 DEPTH OF COMPLETED WELL 165 FLEVATION: D |
| AN "X" IN SECTION BOX: Depth(s) Groundwater Encountered 1. Oft. 2. Oft. 3. Oft. |
| WELL'S STATIC WATER LEVEL 98 ft. below land surface measured on mo/day/yr 03/04/98 Pump testdata: Well water was 0 ft. after 0 hours pumping 0 gpm |
| X Estimated Yield 25 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm i W E Bore Hole Diameter 9 in. to 165 ft., and in. to 0 ft. |
| Bore Hole Diameter 9 in. to 165 ft., and in. to 0 ft. |
| Was a chemical/bacteriological sample submitted to department? No; If yes, mo/day/yr sample was submitted Water well disinfected? Yes |
| 5 TYPE OF BLANK CASING USED: PYC CASING JOINTS: GLUED Blank casing diameter 5 in. to 165 ft., Dia in. to 0 ft., Dia in. to 0 ft. Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21 TYPE OF SCREEN OR PERFORATION MATERIAL: PYC SCREEN OR PERFORATION OPENINGS ARE: SAW CUT |
| SCREEN PERFORATED INTERVALS: From 120 ft. to 160 ft., From 0 ft. to 0 ft. From 0 ft. to 0 ft., From 0 ft. to 0 ft. GRAYEL PACK INTERVALS: From 25 ft. to 165 ft., From 0 ft. to 0 ft. From 0 ft. to 0 ft., From 0 ft. to 0 ft. |
| 4 COOKE MATERIAL PENTONITE |
| Grout Intervals: From 0 ft. to 25 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft. What is the nearest source of possible contamination: NONE - NEW SITE Direction from well? FROM TO LITHOLOGIC LOG FROM TO PLUGGING INTERVALS 0 20 40 CLAY 20 40 CLAY 40 80 CLAY CALACHIE 80 110 CLAY CALACHIE THIN ROCK LAYER 110 120 FINE - MED SAND 120 158 HED-COARSE SAND MEDIUM SAND 158 180 GRAY CLAY THIN ROCK LAYER BLUE SHALE |
| 7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 04/18/98 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This Water Well Record was completed on (mo/day/yr) 05/11/98 under the business name of JOE'S WELL SERVICE, INC. by (signature) |