

1. Location of well: <div style="border: 1px solid black; padding: 2px; display: inline-block;">County Ford Atchafalaya</div>		Fraction SE 1/4 SE 1/4 NW 1/4		Section number 20		Township number T 29 S		Range number R 26 E/W	
2. Distance and direction from nearest town or city: 8 1/2 mi north and 1/2 west of Fowler Street address of well location if in city:					3. Owner of well: Robert Sobba R.R. or street: RFD City, state, zip code: Fowler, Kansas				
4. Locate with "X" in section below: <div style="text-align: center; margin-top: 10px;"><div style="display: flex; justify-content: space-around; align-items: center;"><div style="text-align: center;">N 1 Mile W</div><div style="border: 1px solid black; padding: 5px; text-align: center;"><div style="display: flex; justify-content: space-between;"><div style="width: 45%;">NW</div><div style="width: 45%;">NE</div></div><div style="width: 45%; text-align: center;">X</div><div style="width: 45%;">SW</div><div style="width: 45%;">SE</div></div><div style="text-align: center;">S 1 Mile E</div></div></div>					Sketch map:				
5. Type and color of material					From	To	6. Bore hole dia. 20 in. Completion date 2-2-76 Well depth 170 ft.		
Surface					0	3	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Brown caleche clay					3	27	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Fine to med. sand and gravel (dry)					27	64	9. Casing: Material Metal Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30.30 lbs./ft. Dia. 16 in. to 170 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 7		
1/2 clay 1/2 sand					64	70	10. Screen: Manufacturer's name W.A. Brown Type Free-flow Dia. 16" Slot/gauze 1/8 Length 80" Set between 90 ft. and 170 ft. Gravel pack? Yes Size range of material 3/8 to 1/2 in.		
Med. sand and fine gravel					70	74	11. Static water level: 81' mo./day/yr. 81' ft. below land surface Date 2-5-76		
Yellow and brown clay					74	93	12. Pumping level below land surfaces: 160 ft. after 2 hrs. pumping 250 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 250 g.p.m.		
A-1 sand and gravel					93	120	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Clay with 35% sand & fine gravel mixed					120	140	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
Yellow and brown clay					140	150	15. Well grouted? No With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft.		
Yellow clay with 30% brown rock mixed					150	155	16. Nearest source of possible contamination: NA ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Fine brown sand and brown rock with 10% clay					155	164	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Yellow clay					164	170	18. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name Dodge City, Kansas License No. <input type="checkbox"/> Address Basil C. Jittl Date 5-11-76 Signed <input type="checkbox"/> Authorized representative		
Gray shale with rock layers					170	200	19. Remarks: 10' of grouting and slab to be installed by customer-he knows this is a regulation X Robert Sobba		
(Use a second sheet if needed)									
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley									