


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Gray	SW 1/4 SW 1/4 SW 1/4	34	29	S R 27 EW
2. Distance and direction from nearest town or city: 11 mi south-2 west- 1 south of Ensign Street address of well location if in city:	3. Owner of well: Frank Devine R.R. or street: RFD City, state, zip code: Fowler, Kansas				
4. Locate with "X" in section below: 	Sketch map:				
6. Bore hole dia. 28 in. Completion date 4-20-78 Well depth 220 ft.					
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
9. Casing: Material metal Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.66 lbs./ft. Dia. 16 in. to 220 ft. depth Wall Thickness: 1/8 in. Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 100					
10. Screen: Manufacturer's name W. A. Brown Type 17% Free-flo Dia. 16 Slot/gauze 1/8 Length 151 Set between 69 ft. and 220 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material <input type="checkbox"/> down					
11. Static water level: 50 ft. below land surface Date 3-30-78 mo./day/yr.					
12. Pumping level below land surfaces: 110 ft. after 3 hrs. pumping 2400 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 5000 g.p.m.					
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.					
14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade					
15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type field Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>					
17. Pump: Not installed Manufacturer's name Worthington Model number 15-11 HP 180 Volts <input type="checkbox"/> Length of drop pipe 180 ft. capacity 2200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name Ace-Hi International 190 Address Dodge City, Kansas License No. Signed Carl Gottsch Date 5-19-78 Authorized representative					