

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

_____ T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name	Fraction SE, NE, SE	Section number 35	Town number 295	Range number 27W
Distance and direction from nearest town or city: Approx. 215 and 5E of Cimarron, Ks			3 Owner of well: Wayne Cope 408 Cornell Liberal, Ks			
Street address of well location if in city:			Address:			
Locate with "X" in section below: N			Sketch map:			
2 Type and color of material			From	To	4 Well depth: 280 ft. Date of completion _____ Well diameter 28 in. 15 Aug 75	
<p><i>Well drilled near the site of TH 4-75 (see attached) which is 1320' S. of the NE corner of SE 1/4, sec 35, 29-27 Gray Co., Ks.</i></p>			5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well			
			7 Casing: Material stl Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 280 ft. Weight 37 lbs./ft. Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
			8 Screen: Manufacturer Cook T Foster Type WW T mill slot 16" Slot/gauze 1/8" Length 301 Set between 19 ft. and 280 ft. Fittings: 5.4 - 1.1 mm Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material _____			
			9 Static water level: 61 ft. below land surface Date 22 Apr 75			
			10 Pumping level below land surfaces: 94 ft. after 1 hrs. pumping 2084 g.p.m. 104 ft. after 1 hrs. pumping 2240 g.p.m. Estimated maximum yield 3000 g.p.m.			
			11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
			12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade			
			13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.			
			14 Nearest source of possible contamination: Link ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne Model number 14 Th HP 125 Volts _____ Length of drop pipe 100 ft. capacity 2000 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne - Western Co 150 Business name _____ License No. _____ Address Garden City Signed Pat Vincent Date _____ Authorized representative 11 Sept 75			
(use a second sheet if needed)						

Forward the white, blue and pink copies to the Kansas State Dept. of Health.

Form WWC-5



TEST HOLE REPORT

Layne-Western Company, Inc.

-WATER SUPPLY SERVICES SINCE 1924-

TEST DRILLING • WATER WELLS • PUMPS
P.O. Box 686 - W. Hwy. 50
Garden City, Kansas 67846

Contract Name Wayne Cope

TEST HOLE

Job No. K-538 Date 4-3-75

No 475

City Liberal

State Kansas

State Kansas

Driller McIntyre

Location of Test Hole 1320' South of NE
corner of

A 3x3 grid of empty cells, intended for drawing a 3x3 magic square.

Elevation of Test Hole

1/4 SE 1/4 Sec. 35 of T 29S
R 27W. Gray Co., Kansas

Static Water Level

Measured _____ Hours After Completion

Remarks: