

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Gray	Fraction NE 1/4 SE 1/4 SE 1/4	Section number 20	Township number T 29 S R 28 E	Range number 28
2. Distance and direction from nearest town or city: 3 1/2 miles & 5 south of Montezuma, Kansas				3. Owner of well: Ernest Unruh R.R. or street: RFD City, state, zip code: Montezuma, Kansas 67867		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 7/8 in. Completion date 8-29-77 Well depth 319 ft.		
		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 319 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 265		
5. Type and color of material				From	To	10. Screen: Manufacturer's name Jess & Lowell
Top soil				0	4	Type PVC Dia. 5"
Sandy clay				4	80	Slot 1/8" Length 60'
Med. to lar. sand (some gravel)				80	330	Set between 259 ft. and 319 ft. ft. and 319 ft.
						Gravel pack? Yes Size range of material 1/64-5/32
						11. Static water level: 103 ft. below land surface Date 8/24/77
						12. Pumping level below land surfaces: 104 ft. after 1 hrs. pumping 60 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 70 ± g.p.m.
						13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
						14. Well head completion: _____ Pitless adapter 12 inches above grade
						15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: ft. 10 Direction east Type well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: Transferred Not installed Manufacturer's name customers Windmill Model number _____ HP _____ Volts _____ Length of drop pipe 122 ft. capacity 3 g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal <input checked="" type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name License No. Address Meade, Kansas 67864 Signed <i>[Signature]</i> Date 9-7-77 Authorized representative		
Topography: _____ Hill _____ Slope <input checked="" type="checkbox"/> Upland _____ Valley						

29 28 E
 Sec 20 NE SE SE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5