


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Gray	SE 1/4 NW 1/4 SW 1/4	29	T29	S R 28 E/W
2. Distance and direction from nearest town or city:	From East Side of Montezuma, Ks 7 3/4 South 1 East Street address of well location if in city: 2 North, 1/4 East. 1/4 North		3. Owner of well:	Dallas Koehn	
			R.R. or street:	Montezuma, Ks 67867	
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia. 26 in. Completion date 10-9-75 Well depth 175 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input checked="" type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material	From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <input checked="" type="checkbox"/> Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia 16 in. to 176 in. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth <input type="checkbox"/> gage No. <input type="checkbox"/>		
			10. Screen: Manufacturer's name <input type="checkbox"/> Johnson Division Type Galv. Dia. 16" Slot/gauze Length 20' Set between 130 ft. and 150 ft. Perf 100-130 ft. and 150-175 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1-11 ft. Down		
			11. Static water level: 63 ft. below land surface Date 10-9-75 mo./day/yr.		
			12. Pumping level below land surfaces: 90 ft. after 2 hrs. pumping 805 g.p.m. 112 ft. after 4 hrs. pumping 1140 g.p.m. Estimated maximum yield 1100 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade <input checked="" type="checkbox"/> Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft. <input type="checkbox"/> N/A		
			15. Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> <input type="checkbox"/> N/A		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Goulds-US Pumps Model number 97161 HP 125 Volts <input type="checkbox"/> Length of drop pipe 160 ft. capacity 1100 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	(Use a second sheet if needed)		18. Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Pump Some Fine Sand	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling 208 Business name <input type="checkbox"/> P.O.B. <input type="checkbox"/> A <input type="checkbox"/> Garden City <input type="checkbox"/> Address <input type="checkbox"/> Signed <input type="checkbox"/> Date <input type="checkbox"/> Authorized representative <input type="checkbox"/>

The
Professionals **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

DALLAS KOREE
Gray County
4-2-75

Test # 4

Location: 1/8 mile south of No. 3 test West 1/2 29-29-28

Static Water Level: 80'

0	2	Top soil
2	24	Brown clay
24	67	Brown clay & white rock
67	80	Fine to medium sand& gravel (loose)
80	95	Fine to medium sand & fine gravel 15.5 clay (loose)
95	108	Fine to medium sand & fine gravel (loose)
108	152	Fine to medium sand & gravel (loose)
152	160	Brown clay
160	171	Fine to medium sand & gravel (loose)
171	190	Brown gray & yellow clay with brown rock (hard)

T.D. 175' KAA