

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Gray	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 33	Township number T 29 S R 28	Range number E/W
2. Distance and direction from nearest town or city: Montezuma, Ks. 78/10 miles south -2 east				3. Owner of well: Wilfred Schrepel R.R. or street: 410 N. Sullivan City, state, zip code: Ulysses, Ks. 67880		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>30</u> in. Completion date <u>4/5/77</u> Well depth <u>223</u> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>steel</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.8</u> lbs./ft. Dia. <u>16</u> in. to <u>142.5</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>219</u>		
Surface				From	To	10. Screen: Manufacturer's name <u>Lakewood Pipe of Texas</u>
Clay & lime shells				0	2	Type <u>steel</u> Dia. <u>16"</u> Slot/gauze <u>3/16"</u> Length <u>40.7'</u> Set between <u>142.5</u> ft. and <u>223</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4" x 5/8"</u>
Fine to coarse sand w/clay breakers				2	76	11. Static water level: <u>88</u> ft. below land surface Date <u>3/25/77</u>
Fine sand w/clay breakers				76	105	12. Pumping level below land surfaces: <u>139</u> ft. after <u>6.6</u> hrs. pumping <u>1788</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>2000</u> g.p.m.
Fine to coarse sand w/clay breakers				105	125	13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <input checked="" type="checkbox"/> No Date <u> </u>
Clay & lime w/sand strips				125	183	14. Well head completion: <u> </u> Pitless adapter <u>12</u> Inches above grade
Sandstone (medium tight)				183	210	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <u> </u> Bentonite <u> </u> Concrete <u> </u> Depth: From <u>0</u> ft. to <u>10</u> ft.
				210	223	16. Nearest source of possible contamination: <u>field</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <u> </u> Yes <input checked="" type="checkbox"/> No
						17. Pump: <u>X</u> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <u> </u> Submersible <u> </u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Houck Bros. Drilling Co.</u> License No. <u>164</u> Business name <u>Box 487, Ulysses, Ks.</u> Address <u>M. Beard</u> Signed <u> </u> Authorized representative Date <u>5/25/77</u>
18. Elevation:				19. Remarks:		
Topography: <u> </u> Hill <input checked="" type="checkbox"/> Slope <u> </u> Upland <u> </u> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5