

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 5	Township number T 29	Range number S R 29 W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	3 west & 2 south of Montezuma, Ks.		3. Owner of well: R.R. or street: City, state, zip code:	DeWayne Nickel Montezuma, Kansas 67867	
4. Locate with "X" in section below:	Sketch map: 			6. Bore hole dia. 9 7/8 in. Completion date _____ Well depth 179 ft. 3-11-78	
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Top soil	0	10	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Fine sand	10	32	9. Casing: Material <input checked="" type="checkbox"/> PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.77 lbs./ft. Dia. 5 in. to 179 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 2.58		
Sandy clay	32	100	10. Screen: Manufacturer's name Pumpco Cut		
Med. to lar. sand	100	165	Type PVC Dia. 5" Slot/gauge 20 Length 60' Set between 119 ft. and 179 ft. ft. and ft. Gravel pack? Yes Size range of material 1/64-5/32		
Clay with med. sand streaks	165	180	11. Static water level: mo./day/yr. 106 ft. below land surface Date 3-1-78		
			12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter Unit inches above grade		
			15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
			16. Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: Not installed Manufacturer's name <input checked="" type="checkbox"/> Dempster Model number 100-SE HP 1 Volts 220 Length of drop pipe 168 ft. capacity 15 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name Friesen Windmill 252 Address Meade, Ks. 67864 License No. Signed <i>[Signature]</i> Date 2-29-78 Authorized representative		