


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	GRAY	NE 1/4 SW 1/4 NE 1/4	11	T 29	S R 29 210
2. Distance and direction from nearest town or city: 3 1/2 South, 1 1/4 West 1/8 West, 1/8 South of West side of Montezuma, Ks	Street address of well location if in city.	3. Owner of well: Walter Dirks	R.R. or street: Montezuma, Ks 67867		
4. Locate with "X" in section below:	Sketch map:	6. Bore hole dia. 26 in. Completion date 2-12-76 Well depth 170 ft.			
		<p>7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material <input type="checkbox"/> Steel <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 17 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/></p> <p>10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze <input type="checkbox"/> Length 20' Set between 110 ft. and 160 ft. Perf. 130-140 ft. and 160-170 ft. Gravel pack? YES Size range of material 1/2" Down</p> <p>11. Static water level: <input type="checkbox"/> mo./day/yr. 124 ft. below land surface Date 2-10-76</p> <p>12. Pumping level below land surfaces: 136 ft. after 2 hrs. pumping 300 g.p.m. 115 ft. after 1 hrs. pumping 600 g.p.m. Estimated maximum yield 600 g.p.m.</p> <p>13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/></p> <p>14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade</p> <p>15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 70 ft.</p> <p>16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? Yes <input type="checkbox"/> No <input type="checkbox"/></p> <p>17. Pump: Goulds US Pumps <small>Not installed</small> Manufacturer's name Goulds US Pumps Model number 10JH10 HP 60 Volts 600 Length of drop pipe 160 ft. capacity 600 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other</p> <p>(Use a second sheet if needed)</p> <p>18. Elevation: 19. Remarks: Central well and Pump Co. of Pratt, Ks drilled this well (Lloyd Honomichl)</p> <p>20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name P.O. Box A Garden City KS License No. 63026 Address 14th and 1st Date 6-30-76 Signed Minter Wilson Date 6-30-76 Authorized representative Minter Wilson</p>			

The
Professionals **MINTER-WILSON DRILLING CO.**
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Ivan Jantz (Tenant)
Ella Dirks (OWNER)
Gray County
12-11-75

Location: NE 11-29-29
100 yds. South of his well or $\frac{1}{4}$ mile East of
Test # 1

Static Water Level: 127'

Test # 3

0	2	Top Soil
2	5	Brown Clay
5	20	Brown Sandy Clay
20	37	Brown & White Sandy Clay
37	50	Brown Sandy Clay
50	102	Brown & White Sandy Clay
102	162	Fine to Med. Sand & Gravel (Loose)
162	170	Brown Sandy Clay & White Rock (Hard)