


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Location of well:	County Gray	Fraction 1 1/4 NW 1/4 NW 1/4 NW 1/4	Section number 12	Township number T 29 S	Range number R 29 E/W
Distance and direction from nearest town or city: 3 1/2 S. [redacted] of Montezuma, KS.		3. Owner of well: Diana Lupton			
Street address of well location if in city:		R.R. or street: Montezuma, Kansas 67867			
4. Locate with "X" in section below:		Sketch map:			
		6. Bore hole dia. 9 in. Completion date 1/6/78 Well depth 220 ft.			
		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
		9. Casing: Material PITS Height: Above or below Threaded <input type="checkbox"/> Welded gl Surface 14 in. RMP PVC <input checked="" type="checkbox"/> Weight 10 lbs./ft. Dia. 5 in. to 160 ft. depth Wall Thickness: inches or Dia. 5 in. to ft. depth gage No. 0.258			
5. Type and color of material		From	To	10. Screen: Manufacturer's name J + L Type PVC Dia. 5" Slot/gauze 1/16 Length 60' Set between 160 ft. and 220 ft. ft. and ft. Gravel pack? Yes Size range of material 1/8"	
Overburden		0	126		
Sand + Gravel		126	195		
Clay with Sand + Gravel STKS.		195	220		
				11. Static water level: 126 ft. below land surface Date 1/6/78	
				12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 60 g.p.m.	
				13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date	
				14. Well head completion: Pitless adapter 14 inches above grade	
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 14 ft.	
				16. Nearest source of possible contamination: ft. 60 Direction East Type Corral Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible Turbine <input type="checkbox"/> Jet Reciprocating <input type="checkbox"/> Centrifugal Other	
				18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	
				19. Remarks: #17 Well to be completed by: Dunham Drilling Cawood, KS. 67837	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T+L Water Well 142 Business name Box 816 Liberal, KS License No. Address Box 816 Liberal, KS Signed C. W. Waggoner Date 1/6/78 Authorized representative	