

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NW 1/4 SE 1/4 NE 1/4	Section number 29	Township number T 29 S	Range number R 29 E			
2. Distance and direction from nearest town or city: Street address of well location if in city:	Approximately 6 miles SE of Copeland, Kansas. Edna E. Collingwood Trust R.R. or street: C/O Keith Zody, Box 1184 City, state, zip code: Hutchinson, Kansas 67850							
4. Locate with "X" in section below:	Sketch map: 							
5. Type and color of material	From	To	6. Bore hole dia. 26 in. Completion date 8/15/78 Well depth 390 ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material Steel Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.91 lbs./ft. Dia. 16 in. to 390 ft. depth Wall Thickness inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219 10. Screen: Manufacturer's name W. A. Brown Type Louvered Dia. 16" Slot/gauze .125 Length 160' Set between 210 ft. and 230 ft. 240'-360' ft. and 370'-390' ft. Gravel pack? Yes Size range of material #1 Coarse 11. Static water level: 125 ft. below land surface Date 8/17/78 mo./day/yr. 12. Pumping level below land surfaces: 157 ft. after <input type="checkbox"/> hrs. pumping 1,850 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield K 1,900 g.p.m. 13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr. 14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade 15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. 16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Observed Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other 18. Elevation: <input checked="" type="checkbox"/> Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley 19. Remarks: <p>(Use a second sheet if needed)</p>			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling&Sply 145 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address <input type="checkbox"/> Box 639, Garden City, Ks. Signed Bruce Reichert Date 8/22/78 Authorized representative <input type="checkbox"/>		

DRILLERS TEST LOG

CUSTOMERS NAME	Edna E. Collingwood	DATE	10-4-76					
STREET ADDRESS	Box 1184	TEST #	41 E. Log					
CITY & STATE	Hutchinson, KS	DRILLER	Martinez					
COUNTY	Gray	QUARTER	NE SECTION	29	TOWNSHIP	29	RANGE	29

LOCATION 20' S.E. of center of 1/4

WELL LOCATION

GARDEN CITY, KANSAS
PHONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
IRRIGATION HEADQUARTERS

SUBLETTE, KANSAS
PHONE 675-4311

TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****