



T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

		Township name	Fraction	Section number	Town number	Range number
Location: Gray		Montezuma	NW ₁	31	29	29
Distance and direction from nearest town or city:		5 Miles East and 3½ South of Copeland				
Street address of well location if in city:		Address: Copeland, Kansas				
Locate with "X" in section below:		Sketch map:				
		4 Well depth: 265 ft. Date of completion 12-11-74 Well diameter 26 in.				
		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary				
		6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well				
		7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 265 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight lbs./ft. in. to ft. depth				
2		Type and color of material	From	To	8 Screen: Manufacturer W. A. Brown Type Slot Free Flo 16" Slot/gauze Slot Length 2" Set between 160 ft. and 265 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1x5/8	
		Overburden	0	160		
		Sand & Gravel	160	180		
		Sand, Gravel & Clay Streaks	180	200		
		Coarse Sand	200	220		
		Sand & Gravel	220	260		
		Sand & Gravel (260-275) Clay (275-280)	260	280	9 Static water level: 160 ft. below land surface Date 12-13-74	
		Blue Clay	280	300	10 Pumping level below land surfaces: 160 ft. after hrs. pumping g.p.m. 209 ft. after 4 hrs. pumping 1300 g.p.m. Estimated maximum yield 1400 g.p.m.	
		(use a second sheet if needed)			11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
					12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
					13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From ft. to ft.	
					14 Nearest source of possible contamination: None ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne Model number 1974 HP 100 Volts Length of drop pipe 240 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dunham Drilling 223 Business name <u>Copeland, Kansas</u> License No. Address <u>6-20-75</u> Signed <u>John L. Dunham</u> Date <u>6-20-75</u> Authorized representative	
16 Remarks: elevation Flat level land						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						