



T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

County: Gray		Township name: Montezuma	Fraction: $SE\frac{1}{4}$	Section number: 31	Town number: 29	Range number: 29
Distance and direction from nearest town or city: and Street address of well location if in city:		3 Owner of well: Tony Fisher Copeland, Kansas Address:				
Locate with "X" in section below:		Sketch map:				
		4 Well depth: 320 ft. Date of completion 12-22-74 Well diameter 26 in. 5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well 7 Casing: Material Steel Height: above 200 ft. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 320 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to      ft. depth				
2	Type and color of material		From	To	8 Screen: Manufacturer W. A. Brown Type Free Flo Dia. 16 Slot/gauze slot Length 2" Set between 220 ft. and 320 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 5/8	
	Overburden		0	160	9 Static water level: 152 ft. below land surface Date 12-27-74	
	Coarse Sand & Clay		160	180	10 Pumping level below land surfaces: 170 ft. after 4 hrs. pumping 1400 g.p.m. ft. after      hrs. pumping      g.p.m. Estimated maximum yield 2000 g.p.m.	
	Sand, Gravel, Clay and thin rock streaks		180	200	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
	Sand & Gravel		200	360	12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
					13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From      ft. to      ft.	
					14 Nearest source of possible contamination: None ft.      Direction      Type Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne Model number 1974 HP 150 Volts Length of drop pipe 180 ft. capacity 2000 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(use a second sheet if needed)						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dunham Drilling 223 Business name Address Copeland, Kansas Signed <i>Dunham Drilling</i> Date 6-20-75 Authorized representative
16 Remarks: elevation  Land level						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						