


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Gray	NE 1/4 SE 1/4 SE 1/4	36	T 29	S R 29 E/W
2. Distance and direction from nearest town or city: 10 miles S. of MonteZuma, Kansas	Street address of well location if in city:	3. Owner of well: R.R. or street: City, state, zip code:	Johnnie Juntz Montezuma, KS. 67867		
4. Locate with "X" in section below: 	Sketch map:	6. Bore hole dia. 9 in. Completion date 11/15/75 Well depth 220 ft.			
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <input checked="" type="checkbox"/> P.H. <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight lbs./ft. Dia. 5 in. to 180 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 0-320	
				10. Screen: Manufacturer's name <input type="checkbox"/> Type RMP Dia. 5" <input type="checkbox"/> Slot/gauze 1/16 Length 40 <input type="checkbox"/> Set between 180 ft. and 220 ft. <input type="checkbox"/> ft. and ft. Gravel pack? Yes Size range of material 1/8" <input type="checkbox"/>	
				11. Static water level: mo./day/yr. 120 ft. below land surface Date 11/15/75	
				12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 50 g.p.m.	
				13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date	
				14. Well head completion: Pitless adapter 14 inches above grade	
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.	
				16. Nearest source of possible contamination: ft. Direction Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: #16 New Building Site Well to be completed by: Dunham Drilling Copeland, Kansas
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T+H Water Well 142 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box 816 Liberal, KS Signed <input type="checkbox"/> Date 11/15/75 Authorized representative	