


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County <u>Sedgwick</u>	Fraction <u>1/4 NW 1/4 NW 1/4</u>	Section number <u>2</u>	Township number <u>29</u>	Range number <u>3</u>	E/W <u>W</u>
2. Distance and direction from nearest town or city: <u>4 W of Calmnet, Kansas</u>	3. Owner of well: <u>S. J. Weber</u>		R.R. or street: <u>Viola, Kansas</u>			
Street address of well location if in city: <u>1/4 So.</u>		City, state, zip code: <u>Viola, Kansas</u>				
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 			
5. Type and color of material			From	To	6. Bore hole dia. <u>4 1/2</u> in. Completion date <u>3-17-76</u> Well depth <u>45</u> ft.	
<u>Topsoil</u>			<u>0</u>	<u>3</u>	7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary	
<u>Fine sand</u>			<u>3</u>	<u>15</u>	8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other	
<u>Medium sand</u>			<u>15</u>	<u>30</u>	9. Casing: Material <u>Steel</u> Height: Above or below Threaded: <u>Welded</u> Surface <u>12</u> in. RMP <u>1</u> PVC <u>1</u> Weight <u>15</u> lbs./ft. Dia. <u>5</u> in. to <u>4 1/2</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>4 1/2</u> ft. depth gage No. <u>200</u>	
<u>Shale</u>			<u>30</u>	<u>45</u>	10. Screen: Manufacturer's name <u>Supplaw Plastics</u> Type <u>Styrene</u> Dia. <u>5</u> in. Slot/gauze <u>106</u> Length <u>25</u> ft. Set between <u>20</u> ft. and <u>45</u> ft. <u>7</u> ft. and <u>4 1/2</u> ft. Gravel pack <u>yes</u> size range of material <u>1/4-1/8</u> in.	
					11. Static water level: <u>17</u> ft. below land surface Date <u>3-17-76</u> mo./day/yr.	
					12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
					13. Water sample submitted: ____ mo./day/yr. Yes ____ No ____ Date ____	
					14. Well head completion: <u>12 capped</u> ____ Pitless adapter ____ Inches above grade	
					15. Well grouted? <u>yes</u> With: <u>Neat cement</u> ☒ Bentonite ☒ Concrete Depth: From <u>40</u> to <u>14</u> ft.	
					16. Nearest source of possible contamination: <u>Septic Tank</u> ft. <u>70</u> Direction <u>SE</u> Type <u>Septic Tank</u> Well disinfected upon completion? ☒ Yes ____ No ____	
					17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other	
			(Use a second sheet if needed)			
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Darryl Wells Pump 23</u> Business Name <u>Wichita, Kansas</u> license No. <u>1/4</u> Address <u>Wichita, Kansas</u> Signed <u>M. Arnold</u> Date <u>3-22-76</u> Authorized representative <u>3-22-76</u>			
Topography: ☐ Hill ☒ Slope ☐ Upland ☐ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5