


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County GRAY	Fraction SW 1/4 NW 1/4 NW 1/4	Section number 7	Township number T 29 S	Range number R 30 E	
2. Distance and direction from nearest town or city: Street address of well location if in city: 1 mile W 1/4 North of Copeland				3. Owner of well: Clyde McDougal R.R. or street: City, state, zip code: Copeland, Ks 67837			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. _____ in. Completion date 4-9-76 Well depth 380 ft.			
5. Type and color of material		From	To	7. Cable tool _____ Rotary _____ Driven _____ Dug Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary			
Top Clay		0	75	8. Use: Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____			
SAND & clay		75	170	9. Casing: Material Steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight _____ lbs./ft.			
Coarse Sand		170	210	Dia. 16 in. to 380 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 7			
Clay - yellow & blue		210	230	10. Screen: Manufacturer's name W. A. Brown Ent.			
SAND & clay		230	240	Type Bridge Dia. 16" Slot/gauze slot Length 2" Set between 280' ft. and 380 ft. ft. and _____ ft.			
SAND		240	251	Gravel pack? <input checked="" type="checkbox"/> Size range of material 5/8			
Clay		251	267	11. Static water level: _____ mo./day/yr. 162' ft. below land surface Date 4-9-76			
SAND & clay		267	275	12. Pumping level below land surfaces: 260 ft. after 12 hrs. pumping 1500 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.			
Blue Clay		275	290	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____			
Sand w/s clay		290	322	14. Well head completion: Pitless adapter 12" inches above grade			
Clay		322	326	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.			
SAND		326	338	16. Nearest source of possible contamination: ft. _____ Direction _____ Type None			
Clay - Hard		338	352	Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____			
sand		352	360	17. Pump: _____ Not installed			
Coarse Sand		360	370	Manufacturer's name Layne			
Cemented Sand		370	375	Model number 10181720 HP 100 Volts _____			
Sand		375	378	Length of drop pipe 300 ft. capacity 1500 g.p.m.			
Clay		378	383	Type: Submersible _____ <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____			
Sand		383	386	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Clay		386	405	Signed Dan Dunham Date 4-11-76 Authorized representative			
18. Elevation:		19. Remarks: Machine leveled					
Topography: Hill _____ Slope _____ Upland _____ Valley _____							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5