


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 8	Township number T 29 S	Range number R 30 E		
2. Distance and direction from nearest town or city: Street address of well location if in city:	3. Owner of well: Copeland Township R.R. or street: City, state, zip code: Copeland, Kansas 67837						
4. Locate with "X" in section below: 	Sketch map:						
5. Type and color of material	From	To	6. Bore hole dia. 7 in. Completion date 3/2/77 Well depth 360 ft.				
Overburden	0	149	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
Sand + Gravel	149	350	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
Coarse Sand + Clay	350	360	9. Casing: Material <input checked="" type="checkbox"/> Piles Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 300 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 0.258				
			10. Screen: Manufacturer's name <input checked="" type="checkbox"/> S+L Type <input checked="" type="checkbox"/> PVC Dia. 5" Slot/gauze 1/16 Length 60 Set between 300 ft. and 360 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material. 1/8"				
			11. Static water level: 149 no./day/yr. ft. below land surface Date 3/2/77				
			12. Pumping level below land surfaces: ft. after _____ hrs. pumping _____ g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 100 g.p.m.				
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date				
			14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 14 Inches above grade				
			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.				
			16. Nearest source of possible contamination: ft. 210 Direction NW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
	(Use a second sheet if needed)			18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			
	19. Remarks: Well to be completed by: Dunham Drilling Copeland, KS 67837			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T+W Water Well 142 Business name _____ License No. _____ Address Box 816 Liberal, KS 67701 Signed <u>C. W. Wagoner</u> Date <u>3/2/77</u> Authorized representative _____			