


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: Gray	County	Fraction NE 1/4 SW 1/4 SW 1/4	Section number 9	Township number T 29	Range number S R 30 NW
2. Distance and direction from nearest town or city: $\frac{1}{2}$ East $\frac{3}{4}$ South of Copeland, Ks. Street address or well location if in city:	3. Owner of well: Everett Koelling R.R. or street: Copeland, Ks. 67837 City, state, zip code:				
4. Locate with "X" in section below: 	Sketch map:				
6. Bore hole dia. 26 in. Completion date 12-10-75 Well depth 110 ft.					
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
9. Casing: Material <input type="checkbox"/> Steel Height: Above _____ Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight 36.87 lbs./ft. Dia. 16 in. to 11 ft. depth Wall Thickness: Inches or Dia. 16 in. to 11 ft. depth Gauge No. _____					
10. Screen: Manufacturer's name _____ No Screen Type _____ Dia. _____ Slot/gauge _____ Length _____ Set between 180-228 ft. and 258-410 ft. Pell. 180-228 ft. and 258-410 ft. Gravel pack? <input type="checkbox"/> Yes Size range of material $\frac{1}{2}$ " Down					
11. Static water level: mo./day/yr. 15 ft. below land surface Date 12-9-75					
12. Pumping level below land surfaces: 180 ft. after 2 hrs. pumping 895 g.p.m. 201 ft. after 1 hrs. pumping 1380 g.p.m. Estimated maximum yield 1380 g.p.m.					
13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____					
14. Well head completion: 12 Pitless adapter _____ Inches above grade					
15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. N/A					
16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					
19. Remarks: Customer Furnished his own Pump					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Business name _____ License No. _____ Address: P.O.B. 14 Garden City, Ks. Signed _____ Date _____ Authorized Representative _____					

note MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Everett Koelling
Gray County
10-30-75

Location: SW 9-29-30

From Cemetery East of Copeland, 3/4 mile South,
east side of road.

Static Water Level: 140

Test # 1

0	3	Top Soil
3	19	Brown Clay
19	58	Brown Sandy Clay
58	64	Fine to Med. Sand (Tight)
64	80	Brown & White Sandy Clay
80	93	Fine to Med. Sand & Gravel (Tight)
93	228	Fine to Med. Sand & Gravel (Loose)
228	255	Blue Clay
255	260	Fine to Med. Sand & Gravel, Streaks of Clay(10%)
260	281	Fine to Med. Sand & Gravel, Streaks of Clay(25%)
281	290	Blue Clay, Small Streaks of Fine to Med. Sand (10%)
290	410	Fine to Med. Sand & Gravel (Loose)
410	425	Fine Sand & Clay mixture (Tight)

TD 410