



USE PAPER FOR BALL
POINT PENS PRESS FIRMLY
PRINT CLEARLY

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

County Location of well:	Township name Copeland SW ¹	Fraction SW ⁴	Section number 22	Town number 29	Range number 30
Distance and direction from nearest town or city: 2 Miles East and Street address of well location if in city: 2 Miles South of Copeland		3 Owner of well: Truman McCaslin Copeland, Kansas			
Locate with "X" in section below: 		Sketch map:			
4 Well depth: 300 ft. Date of completion 4-1-75 Well diameter 26 in.					
5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well					
7 Casing: Material steel Height: above bottom Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. Weight lbs./ft. 16 in. to 300 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth					
8 Screen: Manufacturer W A Brown Type Free Flo Dia. 16 Slot/gauze Slot Length 2" Set between 220 ft. and 300 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 5/8					
9 Static water level: 140 ft. below land surface Date 4-1-75					
10 Pumping level below land surfaces: Not Test Pumped ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1200 g.p.m.					
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date					
12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade					
13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From 0 ft. to 10 ft.					
14 Nearest source of possible contamination: None ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No					
15 Pump: Not installed Manufacturer's name Berkley Model number 1950 HP 80 Volts Length of drop pipe 230 ft. capacity 1200 m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
16 Remarks: elevation Machine Level Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dunham Drilling 223 Business name Address Copeland, Kansas 67837 Signed <i>Don Dunham</i> Date 6-20-75 Authorized representative					