RECEIVED
JUN 1975
DIVISION OF ENVIRONMENTAL HEALTH

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY-PRINT CLEARLY

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well: County	Township name	Fraction	Section number	Town number	Range number
Gray	Copeland	NW¼	22	29	30

Distance and direction from nearest town or city: 2 Miles East and 1½ South of Copeland

Street address of well location if in city:

3 Owner of well: Truman McCaslin

Address: Copeland, Kansas

Locate with "X" in section below:



Sketch map:

2 Type and color of material	From	To
Overburden	0	140
Sand & Gravel	140	160
Sand, Gravel and thin clay stks.	160	180
Sand & Gravel	180	420
Coarse sand and clay stks.	420	440
Coarse sand (440-450) Brown Shale (450-460)	440	460
(use a second sheet if needed)		

4 Well depth: 300 ft. Date of completion 3-26-75
Well diameter 26 in.

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary

6 Use: ☐ Domestic ☐ Public supply ☐ Industry
☒ Irrigation ☐ Air conditioning ☐ Commercial
☐ Test well ☐ _____

7 Casing: Material steel Height: above/below
Threaded ☐ Welded ☒ Surface 12 in.
Diam. Weight _____ lbs./ft.
16 in. to 300 ft. depth Drive shoe? ☐ Yes ☒ No
_____ in. to _____ ft. depth

8 Screen:
Manufacturer W. A. Brown
Type Free-Flo Dia. 16
Slot/gauze Slot Length 2"
Set between 220 ft. and 300 ft.
Fittings:
Gravel pack ☒ Yes ☐ No Size range of material 5/8

9 Static water level:
140 ft. below land surface Date 4-1-75

10 Pumping level below land surfaces: Not Test Pumped
_____ ft. after _____ hrs. pumping _____ g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield 1200 g.p.m.

11 Water sample submitted:
☐ Yes ☒ No Date _____

12 Well head completion:
☐ Pitless adapter ☒ Inches above grade

13 Well grouted? ☒ Yes ☐ No
☒ Neat cement ☐ Bentonite ☐ _____
Depth: From 0 ft. to 10 ft.

14 Nearest source of possible contamination: None
ft. _____ Direction _____ Type _____
Well disinfected upon completion? ☐ Yes ☐ No

15 Pump: ☐ Not installed
Manufacturer's name Berkley
Model number 1950 HP 80 Volts _____
Length of drop pipe 230 ft. capacity 1200 g.m.p.
Type:
☐ Submersible ☒ Turbine
☐ Jet ☐ Reciprocating
☐ Certrifugal ☐ Other

16 Remarks: elevation Machine Leveled

Topography:
☐ Hill
☐ Slope
☐ Upland
☐ Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Dunham Drilling 223
Business name License No.
Address Copeland Kansas
Signed _____ Date 6-20-75
Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

677-H