

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 23	Township number T 29	Range number S R 30	EW
2. Distance and direction from nearest town or city:	3 mile East and two south of Copeland		3. Owner of well:	Jesse L. Loucks		
Street address of well location if in city:	R.R. or street: City, state, zip code: Copeland, Kansas 67837					
4. Locate with "X" in section below:	Sketch map:			6. Bore hole dia. _____ in. Completion date 5-23-76 Well depth 240 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <input checked="" type="checkbox"/> Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12" in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. _____ in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 8			
			10. Screen: Manufacturer's name W. A. Brown Ent. Type <input checked="" type="checkbox"/> Bridge Dia. 16" Slot/gauze <input checked="" type="checkbox"/> Slot Length 2" Set between 160 ft. and 240 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 5/8			
			11. Static water level: _____ mo./day/yr. 145' ft. below land surface Date 5-1-76			
			12. Pumping level below land surfaces: 200 ft. after 4 hrs. pumping 1280 g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1500 g.p.m.			
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____			
			14. Well head completion: Pitless adapter 12 inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: None ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			17. Pump: _____ Not installed Manufacturer's name Layne Model number 1976 HP 90 Volts _____ Length of drop pipe 220 ft. capacity 1400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)			18. Elevation: _____ Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: Land leveled by Machine
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dunham Drilling Co. 223 Business name Copeland, Kansas License No. Address _____ Signed  Date 7-2-76 Authorized representative